

Specifications. Public comments requested as to proposed no significant hazards consideration: Yes (60 FR 5739, dated January 30, 1995). The notice provided an opportunity to submit comments on the Commission's proposed no significant hazards consideration determination. No comments have been received. The notice also provided for an opportunity to request a hearing by March 1, 1995, but stated that, if the Commission makes a final no significant hazards consideration determination, any such hearing would take place after issuance of the amendments.

The Commission's related evaluation of the amendments, finding of exigent circumstances, and final determination of no significant hazards consideration is contained in a Safety Evaluation dated February 14, 1995.

Local Public Document Room location: Wharton County Junior College, J. M. Hodges Learning Center, 911 Boling Highway, Wharton, Texas 77488

IES Utilities Inc., Docket No. 50-331, Duane Arnold Energy Center, Linn County, Iowa

Date of application for amendment: August 15, 1994, as supplemented on December 21, 1994, and January 20, 1995. The licensee's submittals of December 21, 1994, and January 20, 1995, provided clarification and did not change the original no significant hazards consideration.

Brief description of amendment: The proposed amendment would revise the Technical Specifications by increasing the allowable main steam isolation valve (MSIV) leakage and deleting the requirements applicable to the MSIV leakage control system.

Date of issuance: February 22, 1995

Effective date: February 22, 1995 and to be implemented within 90 days.

Amendment No.: 207

Facility Operating License No. DPR-49. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: September 14, 1994 (59 FR 47169) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated February 22, 1995. No significant hazards consideration comments received: No.

Local Public Document Room location: Cedar Rapids Public Library, 500 First Street, S. E., Cedar Rapids, Iowa 52401.

Illinois Power Company and Soyland Power Cooperative, Inc., Docket No. 50-461, Clinton Power Station, Unit No. 1, DeWitt County, Illinois

Date of application for amendment: August 12, 1994, as supplemented on October 14, 1994 and February 6, 1995.

Brief description of amendment: The amendment modifies Clinton Power Station Technical Specification 3.6.5.1, "Drywell," to permit a one-time only change to forego performance of the drywell bypass leakage rate test during the fifth refueling outage scheduled to begin in March 1995.

Date of issuance: March 1, 1995

Effective date: March 1, 1995

Amendment No.: 96

Facility Operating License No. NPF-62. The amendment revised the Technical Specifications.

Date of initial notice in Federal Register: September 28, 1994 (59 FR 49427). The October 14, 1994, and February 6, 1995, submittals consisted of revisions and clarifications which did not change the staff's initial proposed no significant hazards consideration determination or expand the scope of the original notice. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 1, 1995. No significant hazards consideration comments received: No

Local Public Document Room

location: The Vespasian Warner Public Library, 120 West Johnson Street, Clinton, Illinois 61727.

Indiana Michigan Power Company, Docket Nos. 50-315 and 50-316, Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2, Berrien County, Michigan

Date of application for amendments: November 18, 1994

Brief description of amendments: The amendments revise Technical Specification 4.0.5 to delete the wording "except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55a(g)(6)(i)." This change allows the licensee to implement certain 10 CFR 50.55a relief requests while the relief requests are being reviewed by the NRC at the beginning of an updated interval.

Date of issuance: February 23, 1995

Effective date: February 23, 1995

Amendment Nos.: 190/176

Facility Operating License Nos. DPR-58 and DPR-74. Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: December 21, 1994 (59 FR 65817) The Commission's related

evaluation of the amendments is contained in a Safety Evaluation dated February 23, 1995. No significant

hazards consideration comments received: No.

Local Public Document Room location: Maud Preston Palenske Memorial Library, 500 Market Street, St. Joseph, Michigan 49085.

Northeast Nuclear Energy Company, et al., Docket No. 50-423, Millstone Nuclear Power Station, Unit No. 3, New London County, Connecticut

Date of application for amendment: May 18, 1994

Brief description of amendment: The amendment modifies the operability requirements for the fuel building exhaust filter system. The amendment will result in modifications to the applicability, surveillance requirement, and bases sections of Technical Specification 3/4.9.12, "Fuel Building Exhaust Filter System."

Date of issuance: February 22, 1995

Effective date: As of the date of issuance to be implemented within 30 days.

Amendment No.: 105

Facility Operating License No. NPF-49. Amendment revised the Technical Specifications.

Date of initial notice in Federal

Register: June 22, 1994 (59 FR 32234) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated February 22, 1995. No significant hazards consideration comments received: No.

Local Public Document Room

location: Learning Resources Center, Three Rivers Community-Technical College, Thames Valley Campus, 574 New London Turnpike, Norwich, CT 06360.

Pacific Gas and Electric Company, Docket Nos. 50-275 and 50-323, Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2, San Luis Obispo County, California

Date of application for amendments: July 9, 1992

Brief description of amendments: The amendments extend the operating licenses for the Diablo Canyon Nuclear Power Plant, Units 1 and 2 to recover or recapture the construction period of the reactors. Specifically, the amendments extend the expiration date of the Unit 1 license from April 23, 2008, to September 22, 2021, and the expiration date of the Unit 2 license from December 9, 2010, to April 26, 2025.

Date of issuance: March 1, 1995

Effective date: March 1, 1995

Amendment Nos.: 97 and 96

Facility Operating License Nos. DPR-80 and DPR-82: The amendments revised the license.

Date of initial notice in Federal

Register: July 22, 1992 (57 FR 32575)