

judgment basis pursuant to 40 CFR 125.3.

Pollutant or pollutant property	BAT effluent limitations micrograms per liter (µg/L)	
	Maximum for any one day	Monthly average
Acetone	ND	ND
Acetonitrile	ND	ND
Ammonia	4,850	3,230
n-Amyl Acetate	105	45
Amyl Alcohol	668	ND
Aniline	10	10
Benzene	ND	ND
2-Butanone (MEK)	202	86
n-Butyl Acetate	87	37
n-Butyl Alcohol	ND	ND
tert-Butyl Alcohol	668	284
Chemical Oxygen Demand (COD)	1,100,000	628,000
Chlorobenzene	ND	ND
Chloroform	ND	ND
Chloromethane	ND	ND
Cyclohexane	ND	ND
o-Dichlorobenzene	ND	ND
1,2-Dichloroethane	100	35
Diethylamine	ND	ND
Diethyl Ether	574	244
Dimethylamine	ND	ND
N,N-Dimethylacetamide	ND	ND
N,N-Dimethylaniline	50	50
N,N-Dimethylformamide	45	19
Dimethyl Sulfoxide	ND	ND
1,4-Dioxane	220	94
Ethanol	ND	ND
Ethyl Acetate	105	45
Ethylene Glycol	ND	ND
Formaldehyde	1,480	623
Formamide	ND	ND
Furfural	2,670	1,140
n-Heptane	ND	ND
n-Hexane	ND	ND
Isobutyraldehyde	1,370	581
Isopropanol	ND	ND
Isopropyl Acetate	87	37
Isopropyl Ether	574	244
Methanol	ND	ND
Methylamine	ND	ND
Methyl Cellosolve	ND	ND
Methyl Formate	105	ND
Methylene Chloride	ND	ND
Methyl Isobutyl Ketone (MIBK)	ND	ND
2-Methylpyridine	50	50
Petroleum Naphtha	ND	ND
Phenol	25	14
Polyethylene glycol 600	4,870	2,070
n-Propanol	ND	ND
Pyridine	10	10
Tetrahydrofuran	910	264
Toluene	ND	ND
Trichlorofluoromethane	ND	ND
Triethylamine	ND	ND
Xylenes	ND	ND

(b) Permittees not using or generating cyanide are deemed to comply with the monitoring requirements specified in paragraph (a) of this section for cyanide if they certify to the permit issuing authority that they are not using or generating this pollutant.

13. Section 439.35 is amended by revising paragraph (a) introductory text and paragraph (b) and by adding paragraph (c) to read as follows:

§ 439.35 New source performance standards (NSPS).

(a) Any new source subject to this subpart that was a "new source" under

40 CFR 122.29 prior to [promulgation date of the final rule] must achieve the following new source performance standards until the expiration of the applicable time period specified in 40 CFR 122.29(d)(1), after which the source must achieve the effluent limitations