

Conditions for Operation applicable to the dual function of the containment vacuum relief isolation lines by specifying the actions that would be required should one or more of the vacuum relief isolation lines by specifying the actions that would be required should one or more of the vacuum relief lines be incapable of performing the containment isolation function or incapable of performing the vacuum relief function.

Date of issuance: April 28, 1995.

Effective date: April 28, 1995.

Amendment No.: 197 and 188.

Facility Operating License Nos. DPR-77 and DPR-79: Amendments revise the technical specifications.

Date of initial notice in Federal Register: May 12, 1994 (58 FR 28060); renounced June 22, 1994 (59 FR 32237), and March 29, 1995 (60 FR 16202).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 28, 1995.

No significant hazards consideration comments received: None.

Local Public Document Room

location: Chattanooga-Hamilton County Library, 1101 Broad Street, Chattanooga, Tennessee 37402.

Tennessee Valley Authority, Docket Nos. 50-327 and 50-328, Sequoyah Nuclear Plant, Units 1 and 2, Hamilton County, Tennessee

Date of application for amendment: November 15, 1994; superseded March 7, 1995 (TS 94-12).

Brief description of amendments: The amendments remove the frequencies specified in the Technical Specifications for performing audits and delete the requirement to perform the Radiological Emergency Plan, Physical Security Plan, and Safeguard Contingency Plan reviews.

Date of issuance: May 10, 1995.

Effective date: May 10, 1995.

Amendment No.: 198 and 189.

Facility Operating License Nos. DPR-77 and DPR-79: Amendments revise the technical specifications.

Date of initial notice in Federal Register: December 21, 1994 (59 FR 65823); renounced March 29, 1995 (60 FR 16203)

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 10, 1995.

No significant hazards consideration comments received: None.

Local Public Document Room

location: Chattanooga-Hamilton County Library, 1101 Broad Street, Chattanooga, Tennessee 37402.

Toledo Edison Company, Centerior Service Company, and The Cleveland Electric Illuminating Company, Docket No. 50-346, Davis-Besse Nuclear Power Station, Unit No. 1, Ottawa County, Ohio

Date of application for amendment: January 30, 1995.

Brief description of amendment: This amendment revises Technical Specification (TS) 4.6.1.2.a, "Containment Systems, Containment Leakage, Surveillance Requirements (SR)" and Bases 3/4.6, "Containment Systems," to state that Type A tests for overall integrated containment leakage rate testing shall be conducted in accordance with the requirements specified in appendix J of 10 CFR part 50, as modified by NRC-approved exemptions. Additionally, TS SR 4.6.1.2.a.

Date of issuance: May 3, 1995.

Effective date: May 3, 1995.

Amendment No.: 198.

Facility Operating License No. NPF-3: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: March 15, 1995 (60 FR 14028).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 3, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room

location: University of Toledo Library, Documents Department, 2801 Bancroft Avenue, Toledo, Ohio 43606.

Virginia Electric and Power Company, et al., Docket Nos. 50-338 and 50-339, North Anna Power Station, Units No. 1 and No. 2, Louisa County, Virginia

Date of application for amendments: July 8, 1993, as supplemented by letters dated July 12, 1994, and March 7, 1995.

Brief description of amendments: The amendments revise the NA-1&2 Technical Specifications by deleting the requirements to periodically review certain administrative and technical procedures.

Date of issuance: May 1, 1995.

Effective date: May 1, 1995.

Amendment Nos.: 190 and 171.

Facility Operating License Nos. NPF-4 and NPF-7: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: August 4, 1993 (58 FR 41518).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated May 1, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room

location: The Alderman Library, Special

Collections Department, University of Virginia, Charlottesville, Virginia 22903-2498.

Virginia Electric and Power Company, et al., Docket Nos. 50-338 and 50-339; North Anna Power Station, Units No. 1 and No. 2, Louisa County, Virginia

Date of application for amendments: December 27, 1993, as supplemented September 6, 1994, and March 7, 1995.

Brief description of amendments: The amendments revise the NA-1&2 Technical Specifications regarding the review responsibilities of the Station Nuclear Safety and Operating Committee and the Management Safety Review Committee.

Date of issuance: May 2, 1995.

Effective date: May 2, 1995.

Amendment Nos.: 191 and 172.

Facility Operating License Nos. NPF-4 and NPF-7: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: February 16, 1994 (59 FR 7700).

The September 6, 1994, and March 7, 1995 submittals provided additional information only, and did not change the staff's initial proposed determination of no significant hazards consideration.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated May 2, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room

location: The Alderman Library, Special Collections Department, University of Virginia, Charlottesville, Virginia 22903-2498.

Virginia Electric and Power Company, Docket Nos. 50-280 and 50-281, Surry Power Station, Unit Nos. 1 and 2, Surry County, Virginia

Date of application for amendments: June 28, 1991.

Brief description of amendments: These amendments incorporate operability and surveillance requirements for power-operated relief valves to conform with Generic Letter 90-06.

Date of issuance: May 2, 1995.

Effective date: May 2, 1995.

Amendment Nos.: 198 and 198.

Facility Operating License Nos. DPR-32 and DPR-37: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: October 2, 1991 (56 FR 49929).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 2, 1995.

No significant hazards consideration comments received: No.