

*Entergy Operations, Inc., Docket No. 50-313, Arkansas Nuclear One, Unit No. 1, Pope County, Arkansas*

*Date of amendment request:* July 22, 1993.

*Brief description of amendment:* The amendment revised the value of the Unit 1 reactor building volume as listed in the technical specifications. The amendment was submitted after a more precise calculation of the reactor building volume was completed.

*Date of issuance:* May 22, 1995.

*Effective date:* May 22, 1995.

*Amendment No.:* 181.

*Facility Operating License No. DPR-51:* Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* December 22, 1993 (58 FR 76843). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 22, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Tomlinson Library, Arkansas Tech University, Russellville, Arkansas 72801.

*Entergy Operations, Inc., System Energy Resources, Inc., South Mississippi Electric Power Association, and Mississippi Power & Light Company, Docket No. 50-416, Grand Gulf Nuclear Station, Unit 1, Claiborne County, Mississippi*

*Date of application for amendment:* June 25, 1993, as supplemented by letter dated April 13, 1995.

*Brief description of amendment:* This amendment deleted portions of the current Technical Specifications (TSs) Surveillance Requirements (SRs) for the inboard Main Steamline Isolation Valve Leakage Control System (MSIV-LCS) heaters and blowers. The deleted MSIV-LCS SRs will be relocated to documents that are included by reference in the Updated Final Safety Analysis Report (UFSAR) and are controlled by the licensee under the provisions of 10 CFR 50.59. The change is consistent with the format and content of the Improved Standard Technical Specifications (NUREG-1434, Revision O).

*Date of issuance:* May 22, 1995.

*Effective date:* May 22, 1995.

*Amendment No.:* 122.

*Facility Operating License No. NPF-29:* Amendment revises the Technical Specifications.

*Date of initial notice in Federal Register:* July 21, 1993 (58 FR 39050). The additional information contained in the supplemental letter dated April 13, 1995, was clarifying in nature and thus, within the scope of the initial notice

and did not affect the staff's proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 22, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Judge George W. Armstrong Library, 220 S. Commerce Street, Natchez, MS 39120.

*Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, City of Dalton, Georgia, Docket Nos. 50-424 and 50-425, Vogtle Electric Generating Plant, Units 1 and 2, Burke County, Georgia*

*Date of application for amendments:* March 18, 1994, as supplemented by letters dated February 28 and March 17, 1995.

*Brief description of amendments:* The amendments revise Technical Specification (TS) 3/4.3.3.6, Accident Monitoring Instrumentation, TS 3/4.6.4.1, Hydrogen Monitors, and their associated Bases to incorporate the technical substance of Specification 3.3.3 from NUREG-1431, Revision O (Standard Technical Specifications) for the Westinghouse Owners Group.

*Date of issuance:* May 15, 1995.

*Effective date:* As of the date of issuance to be implemented within 30 days.

*Amendment Nos.:* 85 and 63.

*Facility Operating License Nos. NPF-68 and NPF-81:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal*

*Register:* April 28, 1994 (59 FR 22008). The February 28 and March 17, 1995, letters provided clarifying information that did not change the scope of the March 18, 1994, application and initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated May 15, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Burke County Library, 412 Fourth Street, Waynesboro, Georgia 30830.

*Houston Lighting & Power Company, City Public Service Board of San Antonio, Central Power and Light Company, City of Austin, Texas, Docket Nos. 50-498 and 50-499, South Texas Project, Units 1 and 2, Matagorda County, Texas*

*Date of amendment request:* March 16, 1995.

*Brief description of amendments:* The amendments revised Technical Specification 4.6.1.2, regarding the test frequency requirements for the overall integrated containment leakage rate tests, so that it references 10 CFR part 50, appendix J and approved exemptions, rather than paraphrase the regulation.

*Date of issuance:* May 19, 1995.

*Effective date:* May 19, 1995.

*Amendment Nos.:* Unit 1—Amendment No. 75; Unit 2—Amendment No. 64.

*Facility Operating License Nos. NPF-76 and NPF-80:* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* April 26, 1995 (60 FR 20517). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated May 19, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Wharton County Junior College, J. M. Hodges Learning Center, 911 Boling Highway, Wharton, Texas 77488.

*Maine Yankee Atomic Power Company, Docket No. 50-309, Maine Yankee Atomic Power Station, Lincoln County, Maine*

*Date of application for amendment:* April 14, 1995.

*Brief description of amendment:* The amendment allows the use of the Westinghouse Electric Corporation sleeving process for repairing steam generator tubes.

*Date of issuance:* May 22, 1995.

*Effective date:* As of the date of issuance to be implemented within 30 days.

*Amendment No.:* 150.

*Facility Operating License No. DPR-36:* Amendment revised the Technical Specifications.

*Date of initial notice in Federal*

*Register:* April 22, 1995 (60 FR 19969). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 22, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Wiscasset Public Library, High Street, P.O. Box 367, Wiscasset, ME 04578.

*North Atlantic Energy Service Corporation, Docket No. 50-443, Seabrook Station, Unit No. 1, Rockingham County, New Hampshire*

*Date of amendment request:* January 25, 1995, and oral request of May 16, 1995.

*Description of amendment request:* This amendment revises the Appendix