

*Local Public Document Room location:* Government Publications Section, State Library of Pennsylvania, (REGIONAL DEPOSITORY) Education Building, Walnut Street and Commonwealth Avenue, Box 1601, Harrisburg, Pennsylvania 17105.

*Public Service Electric & Gas Company, Docket Nos. 50-272 and 50-311, Salem Nuclear Generating Station, Unit Nos. 1 and 2, Salem County, New Jersey*

*Date of application for amendments:* September 29, 1994.

*Brief description of amendments:* The amendments remove from the Technical Specifications the sections entitled "Seismic Instrumentation" and "Meteorological Instrumentation" and relocate the information and testing requirements to the Salem Updated Final Safety Analysis Report.

*Date of issuance:* May 22, 1995.

*Effective date:* May 22, 1995.

*Amendment Nos. 167 and 149.*

*Facility Operating License Nos. DPR-70 and DPR-75.* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 23, 1994 (59 FR 60385). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated May 22, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room location:* Salem Free Public Library, 112 West Broadway, Salem, New Jersey 08079.

*Southern California Edison Company, et al., Docket Nos. 50-361 and 50-362, San Onofre Nuclear Generating Station, Unit Nos. 2 and 3, San Diego County, California*

*Date of application for amendments:* November 3, 1993.

*Brief description of amendments:* These amendments revise Technical Specification (TS) 3/4.6.3,

"Containment Isolation Valves," to require valves listed in Section D of existing Table 3.6-1, "Containment Isolation Valves," to be in an action statement when secured in their engineered safety feature actuation system (ESFAS) actuated position. Bases 3/4.6.3 is also revised to reflect these changes.

*Date of issuance:* May 17, 1995.

*Effective date:* May 17, 1995, to be implemented within 30 days of issuance.

*Amendment Nos.:* Unit 2—Amendment No. 119; Unit 3—Amendment No. 108.

*Facility Operating License Nos. NPF-10 and NPF-15:* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* February 16, 1994 (59 FR

7699). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated May 17, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room location:* Main Library, University of California, P. O. Box 19557, Irvine, California 92713.

*Virginia Electric and Power Company, et al., Docket Nos. 50-338 and 50-339, North Anna Power Station, Units No. 1 and No. 2, Louisa County, Virginia*

*Date of application for amendments:* October 25, 1994.

*Brief description of amendments:* The amendments revise the NA-1&2 Hydrogen Recombiner System surveillance requirements in accordance with Generic Letter 93-05, "Line-Item Technical Specification Improvements to Reduce Surveillance Requirements for Testing During Power Operation." Also, the amendments delete the surveillance requirement to operate the containment purge blower and clarifies that the surveillance requirement applies only to the hydrogen recombinder purge blowers.

*Date of issuance:* May 12, 1995.

*Effective date:* May 12, 1995.

*Amendment Nos.:* 192 and 173.

*Facility Operating License Nos. NPF-4 and NPF-7.* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 23, 1994 (59 FR 60388). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated May 12, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room location:* The Alderman Library, Special Collections Department, University of Virginia, Charlottesville, Virginia 22903-2498.

*Virginia Electric and Power Company, et al., Docket Nos. 50-338 and 50-339, North Anna Power Station, Units No. 1 and No. 2, Louisa County, Virginia*

*Date of application for amendments:* March 2, 1995.

*Brief description of amendments:* The amendments revise the NA-1&2 Technical Specification 4.6.1.2.a to permit approved exemptions to the containment integrated leak rate test frequency requirements.

*Date of issuance:* May 15, 1995.

*Effective date:* May 15, 1995.

*Amendment Nos.:* 193 and 174.

*Facility Operating License Nos. NPF-4 and NPF-7:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* April 12, 1995 (60 FR 18629). The Commission's related evaluation of the amendments is contained in a Safety

Evaluation dated May 15, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room location:* The Alderman Library, Special Collections Department, University of Virginia, Charlottesville, Virginia 22903-2498.

*Washington Public Power Supply System, Docket No. 50-397, Nuclear Project No. 2, Benton County, Washington*

*Date of application for amendments:* September 2, 1992.

*Brief description of amendment:* The amendment revises Figure 3.1.5-2, "Sodium Pentaborate Tank, Volume Vs. Concentration Requirements," to reflect the actual low-volume-alarm and low-limit values for the standby liquid control tank.

*Date of issuance:* May 17, 1995.

*Effective date:* May 17, 1995, to be implemented within 30 days of issuance.

*Amendment No.:* 138.

*Facility Operating License No. NPF-21:* The amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 23, 1994 (59 FR 60388). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 17, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room location:* Richland Public Library, 955 Northgate Street, Richland, Washington 99352.

*Wolf Creek Nuclear Operating Corporation, Docket No. 50-482, Wolf Creek Generating Station, Coffey County, Kansas*

*Date of amendment request:* March 21, 1995.

*Brief description of amendment:* This amendment revises Technical Specification Surveillance Requirement 4.6.2.1.d, "Containment Spray System," to change the surveillance interval specified for the performance of an air or smoke flow test through the containment spray header from at least 5 years to at least once per 10 years.

*Date of issuance:* May 17, 1995.

*Effective date:* May 17, 1995, to be implemented within 30 days of issuance.

*Amendment No.:* 86.

*Facility Operating License No. NPF-42:* The amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* April 12, 1995 (60 FR 18631). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 17, 1995. No