

*Brief description of amendments:* The proposed amendments revise surveillance requirements (SRs) as recommended by NRC Generic Letter (GL) 93-05, "Line-Item Technical Specification Improvements to Reduce Surveillance Requirements for Testing During Power Operation" of the combined Technical Specifications (TS) for the Diablo Canyon Nuclear Power Plant Unit Nos. 1 and 2. The specific TS changes are as follows:

(1) TS SR 4.1.3.1.2 is revised to change the frequency for testing the movability of the control rods from at least once per 31 days to at least once per 92 days.

(2) TS 3/4.3.2, Table 4.3-2, "Engineered Safety Features Actuation System Instrumentation Surveillance Requirements," Functional Unit 3.c.4), and TS 3/4.3.3.1, Table 4.3-3, "Radiation Monitoring Instrumentation for Plant Operations SRs," is revised to change the monthly channel functional test to quarterly.

(3) TS 3/4.5.1 is changed as follows: (a) TS SR 4.5.1.1a.1) is revised to more clearly state that the accumulator water volume and pressure must be verified to be within their limits. (b) TS SR 4.5.1.1b. is revised to specify that the boron concentration surveillance is not required to be performed if the accumulator makeup source was the refueling water storage tank (RWST). (c) TS SR 4.5.1.2 is relocated to plant procedures.

(4) TS SR 4.5.2c.2) is revised to clarify that a separate containment entry to verify the absence of loose debris is not required after each containment entry.

(5) TS SR 4.6.2.1d. is revised to change the frequency for a containment spray header flow test from at least once per 5 years to at least once per 10 years.

(6) TS SR 4.6.4.2a. is revised to change the verification of the minimum hydrogen recombiner sheath temperature from at least once per 6 months to at least once each refueling interval.

(7) TS SR 4.7.1.2.1 is revised to change the surveillance frequency for testing each auxiliary feedwater (AFW) pump from at least once per 31 days to at least once per 92 days on a staggered test basis.

(8) TS SR 4.10.1.2 is revised to lengthen the allowed period of time for a rod drop test from 24 hours to 7 days prior to reducing shutdown margin to less than the limits of TS 3.1.1.1.

(9) TS SR 4.11.2.6 is revised to change the surveillance frequency from 24 hours to 7 days when radioactive material is being added to the gas decay tanks and to add a requirement to monitor radioactive material

concentrations in the gas decay tanks at least once per 24 hours when system degassing operations are in progress.

*Date of issuance:* May 26, 1995

*Effective date:* May 26, 1995, to be implemented within 60 days of issuance.

*Amendment Nos.:* Unit 1 - Amendment No. 102; Unit 2 - Amendment No. 101

*Facility Operating License Nos.* DPR-80 and DPR-82: The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* October 26, 1994 (59 FR 53843) The April 14, 1995, letter provided clarifying information and did not change the initial no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated May 26, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* California Polytechnic State University, Robert E. Kennedy Library, Government Documents and Maps Department, San Luis Obispo, California 93407.

**Pacific Gas and Electric Company, Docket Nos. 50-275 and 50-323, Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2, San Luis Obispo County, California**

*Date of application for amendments:* December 30, 1994 (LAR 94-12)

*Brief description of amendments:* These amendments clarify the technical specifications (TS) issued in license amendments 84/83 associated with the Eagle 21 reactor protection system modification, delete TS references to RM-14A and RM-14B, remove cycle-specific TS requirements, and incorporate editorial corrections.

*Date of issuance:* June 2, 1995

*Effective date:* June 2, 1995, to be implemented within 30 days of issuance.

*Amendment Nos.:* Unit 1 - Amendment No. 103; Unit 2 - Amendment No. 102

*Facility Operating License Nos.* DPR-80 and DPR-82: The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* March 15, 1995 (60 FR 14026) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 2, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* California Polytechnic State University, Robert E. Kennedy Library, Government Documents and Maps

Department, San Luis Obispo, California 93407.

**Pacific Gas and Electric Company, Docket Nos. 50-275 and 50-323, Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2, San Luis Obispo County, California**

*Date of application for amendments:* February 6, 1995, as supplemented by letters dated March 23, 1995, and May 22, 1995.

*Brief description of amendments:* The amendments would allow the storage of fuel with enrichments up to and including 5.0 weight percent U-235, would clarify that substitution of fuel rods with filler rods is acceptable for fuel designs that have been analyzed with applicable NRC-approved codes and methods, and would allow the use of ZIRLO fuel cladding in the future in addition to Zircaloy-4.

*Date of issuance:* June 7, 1995

*Effective date:* June 7, 1995, to be implemented within 30 days of issuance.

*Amendment Nos.:* Unit 1 - Amendment No. 104; Unit 2 - Amendment No. 103

*Facility Operating License Nos.* DPR-80 and DPR-82: The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* March 1, 1995 (60 FR 11138) The licensee's supplemental letters provided additional clarifying information. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 7, 1995. No significant hazards consideration comments received: Yes. Comments were submitted by Jill ZamEk on behalf of the San Luis Obispo Mothers for Peace by letter dated March 30, 1995.

*Local Public Document Room*

*location:* California Polytechnic State University, Robert E. Kennedy Library, Government Documents and Maps Department, San Luis Obispo, California 93407.

**Pacific Gas and Electric Company, Docket No. 50-133, Humboldt Bay Power Plant, Unit 3, Humboldt County, California**

*Date of application for amendment:* November 23, 1994, as supplemented April 27, 1995.

*Brief description of amendment:* This amendment revised the Technical Specifications Section VII.C., Plant Staff, to decrease the minimum staff requirements for the shift operating organization from five to two persons.

*Date of issuance:* May 31, 1995

*Effective date:* This license amendment is effective as of the date of