

No significant hazards consideration comments received. No.

Local Public Document Room
location: Government Documents
Department, Louisiana State University,
Baton Rouge, Louisiana 70803.

PECO Energy Company, Public Service Electric and Gas Company, Delmarva Power and Light Company, and Atlantic City Electric Company, Docket Nos. 50-277 and 50-278, Peach Bottom Atomic Power Station, Unit Nos. 2 and 3, York County, Pennsylvania

Date of application for amendments:
November 17, 1994 as supplemented
March 30, 1995.

Brief description of amendments: The amendments change equipment designations, instrument range descriptions, instrument setpoints and surveillance requirements in the Peach Bottom Technical Specifications to reflect planned modifications to the main stack and vent stack radiation monitoring systems.

Date of issuance: June 13, 1995.

Effective date: June 13, 1995.

Amendments Nos.: 204 and 207.

Facility Operating License Nos. DPR-44 and DPR-56: The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: March 15, 1995 (60 FR 14027)
The March 30, 1995, submittal provided clarifying information that did not change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 13, 1995.

No significant hazards consideration comments received. No.

Local Public Document Room
location: Government Publications
Section, State Library of Pennsylvania,
(REGIONAL DEPOSITORY) Education
Building, Walnut Street and
Commonwealth Avenue, Box 1601,
Harrisburg, Pennsylvania 17105.

PECO Energy Company, Public Service Electric and Gas Company, Delmarva Power and Light Company, and Atlantic City Electric Company, Docket Nos. 50-277 and 50-278, Peach Bottom Atomic Power Station, Unit Nos. 2 and 3, York County, Pennsylvania

Date of application for amendments:
March 16, 1995.

Brief description of amendments:
These amendments change the existing Technical Specification requirements for source range neutron monitoring equipment while in the refueling mode to requirements based on NUREG-1433, "Standard Technical Specifications General Electric Plants, BWR/4."

Date of issuance: June 13, 1995.

Effective date: June 13, 1995.

Amendments Nos.: 205 and 208.

Facility Operating License Nos. DPR-44 and DPR-56: The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: May 10, 1995 (60 FR 24913)
The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 13, 1995.

No significant hazards consideration comments received. No.

Local Public Document Room
location: Government Publications
Section, State Library of Pennsylvania,
(REGIONAL DEPOSITORY) Education
Building, Walnut Street and
Commonwealth Avenue, Box 1601,
Harrisburg, Pennsylvania 17105.

PECO Energy Company, Public Service Electric and Gas Company, Delmarva Power and Light Company, and Atlantic City Electric Company, Docket No. 50-277, Peach Bottom Atomic Power Station, Unit No. 2, York County, Pennsylvania

Date of application for amendment:
March 30, 1995, as supplemented by
letter dated May 26, 1995.

Brief description of amendment: The proposed amendment revises Technical Specification Section 4.7.D.1.b(1) by adding a footnote to exempt the High Pressure Coolant Injection motor-operated valve MO-2-23-015 from quarterly stroke testing requirements until refueling outage 2RO11.

Date of issuance: June 13, 1995.

Effective date: June 13, 1995.

Amendment No.: 206.

Facility Operating License No. DPR-44: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: May 10, 1995 (60 FR 24912)
The May 26, 1995, submittal provided clarifying information that did not change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 13, 1995.

No significant hazards consideration comments received. No.

Local Public Document Room
location: Government Publications
Section, State Library of Pennsylvania,
(REGIONAL DEPOSITORY) Education
Building, Walnut Street and
Commonwealth Avenue, Box 1601,
Harrisburg, Pennsylvania 17105.

PECO Energy Company, Public Service Electric and Gas Company, Delmarva Power and Light Company, and Atlantic City Electric Company, Docket Nos. 50-277 and 50-278, Peach Bottom Atomic Power Station, Unit Nos. 2 and 3, York County, Pennsylvania

Date of application for amendments:
March 22, 1995.

Brief description of amendments:
These amendments reduce the local leak rate test hold time specified in the Technical Specification Tables 3.7.2 through 3.7.4 from one hour to 20 minutes.

Date of issuance: June 19, 1995.

Effective date: June 19, 1995.

Amendments Nos.: 207 and 209.

Facility Operating License Nos. DPR-44 and DPR-56: The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: May 10, 1995 (60 FR 24913).
The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 19, 1995.

No significant hazards consideration comments received. No.

Local Public Document Room
location: Government Publications
Section, State Library of Pennsylvania,
(REGIONAL DEPOSITORY) Education
Building, Walnut Street and
Commonwealth Avenue, Box 1601,
Harrisburg, Pennsylvania 17105.

Pennsylvania Power and Light Company, Docket Nos. 50-387 and 50-388 Susquehanna Steam Electric Station, Units 1 and 2, Luzerne County, Pennsylvania

Date of application for amendments:
October 28, 1994, as supplemented by
letter dated April 18, 1995.

Brief description of amendments:
These amendments delete, from the Technical Specifications, the surveillance and operability requirements for chlorine detection and the associated Bases as a result of the removal of bulk quantities of gaseous chlorine from the site.

Date of issuance: June 19, 1995.

Effective date: As of the date of issuance, to be implemented within 30 days.

Amendment Nos.: 147 and 117.

Facility Operating License Nos. NPF-14 and NPF-22. The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: December 21, 1994 (59 FR 65821). The April 18, 1995, letter provided clarifying information that did not change the initial proposed no significant hazards consideration determination.