

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 19, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Osterhout Free Library, Reference Department, 71 South Franklin Street, Wilkes-Barre, Pennsylvania 18701.

*Philadelphia Electric Company, Docket Nos. 50-352 and 50-353, Limerick Generating Station, Units 1 and 2, Montgomery County, Pennsylvania*

*Date of application for amendments:* August 31, 1994.

*Brief description of amendments:* This amendment revises the Technical Specifications to permit the operability requirement for the Feedwater/Main Turbine Trip System Actuation Instrumentation to be Operational Condition 1 greater than or equal to 25% Rated Thermal Power.

*Date of issuance:* June 13, 1995.

*Effective date:* June 13, 1995.

*Amendment Nos. 91 and 55.*

*Facility Operating License Nos. NPF-39 and NPF-85.* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 9, 1994 (59 FR 55884) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 13, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Pottstown Public Library, 500 High Street, Pottstown, Pennsylvania 19464.

*Philadelphia Electric Company, Docket Nos. 50-352 and 50-353, Limerick Generating Station, Units 1 and 2, Montgomery County, Pennsylvania*

*Date of application for amendments:* August 23, 1994.

*Brief description of amendments:* Remove the 125/250 Vdc Class 1E Battery Load Cycle Table from the technical specifications (TS) and rephrase the surveillance requirements to be consistent with NUREG-1433, "Standard Technical Specifications", and correct Amendments 71 and 34, dated June 28, 1994, to change certain surveillance requirement intervals from 24 months to 18 months.

*Date of issuance:* June 19, 1995.

*Effective date:* June 19, 1995.

*Amendment Nos. 92 and 56.*

*Facility Operating License Nos. NPF-39 and NPF-85.* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* October 12, 1994 (59 FR

51624) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 19, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Pottstown Public Library, 500 High Street, Pottstown, Pennsylvania 19464.

*Philadelphia Electric Company, Docket Nos. 50-352 and 50-353, Limerick Generating Station, Units 1 and 2, Montgomery County, Pennsylvania*

*Date of application for amendments:* August 31, 1994.

*Brief description of amendments:* These amendments relocate the requirements of TS 3/4.8.4.1, "Primary Containment Penetration Conductor Overcurrent Protective Devices," to the Updated Final Safety Analysis Report and plant procedures.

*Date of issuance:* June 22, 1995.

*Effective date:* June 22, 1995.

*Amendment Nos. 93 and 57.*

*Facility Operating License Nos. NPF-39 and NPF-85.* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 9, 1994 (59 FR 55884) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 22, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Pottstown Public Library, 500 High Street, Pottstown, Pennsylvania 19464.

*Philadelphia Electric Company, Docket Nos. 50-352 and 50-353, Limerick Generating Station, Units 1 and 2, Montgomery County, Pennsylvania*

*Date of application for amendments:* August 12, 1994, as supplemented by letter dated March 29, 1995.

*Brief description of amendments:* These amendments revise the action statements regarding emergency core cooling systems to allow continued operation in the event that the high pressure coolant injection system, one core spray subsystem and/or one low pressure coolant injection subsystem are inoperable.

*Date of issuance:* June 22, 1995.

*Effective date:* As of the date of issuance to be implemented within 30 days.

*Amendment Nos. 94 and 58.*

*Facility Operating License Nos. NPF-39 and NPF-85.* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* October 12, 1994 (59 FR

51623). The March 29, 1995, letter provided clarifying information that did not change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 22, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Pottstown Public Library, 500 High Street, Pottstown, Pennsylvania 19464.

*Philadelphia Electric Company, Docket Nos. 50-352 and 50-353, Limerick Generating Station, Units 1 and 2, Montgomery County, Pennsylvania*

*Date of application for amendments:* August 31, 1994.

*Brief description of amendments:* The amendments permit the operability of one Low Pressure Coolant Injection subsystem of Residual Heat Removal while the subsystem is aligned and operating in the Shutdown Cooling Mode during Operational Conditions (OPCONs) 4 and 5.

*Date of issuance:* June 22, 1995.

*Effective date:* June 22, 1995.

*Amendment Nos. 95 and 59.*

*Facility Operating License Nos. NPF-39 and NPF-85.* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 9, 1994 (59 FR 55884). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 22, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Pottstown Public Library, 500 High Street, Pottstown, Pennsylvania 19464.

*Public Service Electric & Gas Company, Docket Nos. 50-272 and 50-311, Salem Nuclear Generating Station, Unit Nos. 1 and 2, Salem County, New Jersey*

*Date of application for amendments:* November 18, 1994.

*Brief description of amendments:* The amendments revise the Reactivity Control System Technical Specification Limiting Conditions for Operation for boration flow paths and charging pumps by reducing the number of operable charging pumps required for boron addition in Mode 4 from two to one.

*Date of issuance:* June 12, 1995.

*Effective date:* As of the date of issuance, to be implemented within 60 days.

*Amendment Nos. 169 and 151.*

*Facility Operating License Nos. DPR-70 and DPR-75.* The amendments revised the Technical Specifications.