

*Date of initial notice in Federal Register:* January 4, 1995 (60 FR 505). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 12, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room location:* Salem Free Public Library, 112 West Broadway, Salem, New Jersey 08079.

*Public Service Electric & Gas Company, Docket Nos. 50-272 and 50-311, Salem Nuclear Generating Station, Unit Nos. 1 and 2, Salem County, New Jersey*

*Date of application for amendments:* June 29, 1994, as supplemented August 8, 1994, and May 2, 1995.

*Brief description of amendments:* The amendments increase the Technical Specification minimum volume of emergency diesel generator fuel oil contained in the Diesel Fuel Oil Storage Tanks at both units of the Salem station.

*Date of issuance:* June 20, 1995.

*Effective date:* As of the date of issuance, to be implemented within 60 days.

*Amendment Nos. 170 and 152.*

*Facility Operating License Nos. DPR-70 and DPR-75.* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* August 17, 1994 (59 FR 42346). The August 8, 1994, and May 2, 1995, letters provided clarifying information that did not change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 20, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room location:* Salem Free Public Library, 112 West Broadway, Salem, New Jersey 08079.

*South Carolina Electric & Gas Company, South Carolina Public Service Authority, Docket No. 50-395, Virgil C. Summer Nuclear Station, Unit No. 1, Fairfield County, South Carolina*

*Date of application for amendment:* March 6, 1995, as supplemented on May 5, 1995 and June 6, 1995.

*Brief description of amendment:* The amendment deletes a license condition that required the licensee to maintain a seismic monitoring network around the Monticello Reservoir.

*Date of issuance:* June 13, 1995.

*Effective date:* June 13, 1995.

*Amendment No.: 124.*

*Facility Operating License No. NPF-12.* Amendment revises the operating license.

*Date of initial notice in Federal Register:* March 29, 1995 (60 FR 16201). The May 5, 1995 and June 6, 1995 submittals provided supplemental information that did not change the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 13, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room location:* Fairfield County Library, 300 Washington Street, Winnsboro, SC 29180.

*Tennessee Valley Authority, Docket Nos. 50-259, 50-260 and 50-296, Browns Ferry Nuclear Plant, Units 1, 2 and 3, Limestone County, Alabama*

*Date of application for amendments:* November 15, 1994; superseded March 7, 1995 (TS 350).

*Brief Description of amendment:* The amendments remove the frequencies specified in the Technical Specifications for performing audits and delete the requirement to perform the Radiological Emergency Plan, Physical Security Plan, and Safeguard Contingency Plan reviews.

*Date of issuance:* June 19, 1995.

*Effective Date:* June 19, 1995.

*Amendment Nos.: 221, 236 and 195.*

*Facility Operating License Nos. DPR-33, DRP-52 and DPR-68:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* December 21, 1994 (59 FR 65823); superseded March 29, 1995 (60 FR 16202). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 19, 1995.

No significant hazards consideration comments received: None.

*Local Public Document Room Location:* Athens Public Library, South Street, Athens, Alabama 35611.

*Tennessee Valley Authority, Docket Nos. 50-327 and 50-328, Sequoyah Nuclear Plant, Units 1 and 2, Hamilton County, Tennessee*

*Date of application for amendments:* April 6, 1995 (TS 95-02).

*Brief description of amendments:* The amendments add a limiting condition for operation that allows equipment to be returned to service under administrative control to perform operability testing and establishes the time interval to place an inoperable channel in the bypass condition.

*Date of issuance:* June 13, 1995.

*Effective date:* June 13, 1995.

*Amendment Nos.: 202 and 192.*

*Facility Operating License Nos. DPR-77 and DPR-79:* Amendments revise the technical specifications.

*Date of initial notice in Federal Register:* April 26, 1995 (60 FR 20530). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 13, 1995.

No significant hazards consideration comments received: None.

*Local Public Document Room location:* Chattanooga-Hamilton County Library, 1101 Broad Street, Chattanooga, Tennessee 37402.

*Tennessee Valley Authority, Docket Nos. 50-327 and 50-328, Sequoyah Nuclear Plant, Units 1 and 2, Hamilton County, Tennessee*

*Date of application for amendments:* April 6, 1995 (TS 95-05).

*Brief description of amendments:* The amendments revise the technical specifications by deleting Tables 3.6-1, 3.6-2, and 3.8-2 and referenced to them, incorporating related guidance and justification, and modifying the specification related to electrical equipment protective devices in accordance with Generic Letter 91-08.

*Date of issuance:* June 13, 1995.

*Effective date:* June 13, 1995.

*Amendment Nos.: 203 and 193.*

*Facility Operating License Nos. DPR-77 and DPR-79:* Amendments revise the technical specifications.

*Date of initial notice in Federal Register:* May 10, 1995 (60 FR 24919). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 13, 1995.

No significant hazards consideration comments received: None.

*Local Public Document Room location:* Chattanooga-Hamilton County Library, 1101 Broad Street, Chattanooga, Tennessee 37402.

*Tennessee Valley Authority, Docket Nos. 50-327 and 50-328, Sequoyah Nuclear Plant, Units 1 and 2, Hamilton County, Tennessee*

*Date of application for amendments:* April 6, 1995 (TS 95-06).

*Brief description of amendments:* The amendments remove the technical specification requirements related to crane travel over the spent fuel pool.

*Date of issuance:* June 14, 1995.

*Effective date:* June 14, 1995.

*Amendment Nos.: 204 and 194.*

*Facility Operating License Nos. DPR-77 and DPR-79:* Amendments revise the technical specifications.

*Date of initial notice in Federal Register:* April 26, 1995 (60 FR 20529). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 14, 1995.