

*Brief description of amendments:* This amendment makes changes to Technical Specification 6.2.3, Independent Safety Engineering group. The change maintains the requirement to perform independent technical reviews while providing increased flexibility to accomplish this function.

*Date of Issuance:* December 22, 1994.

*Effective Date:* December 22, 1994.

*Amendment Nos.:* 69.

*Facility Operating License Nos. DPR-67 and NPF-16:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* October 27, 1993 (58 FR 57851). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated December 22, 1994.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Indian River Junior College Library, 3209 Virginia Avenue, Fort Pierce, Florida 34954-9003.

**Florida Power and Light Company, Docket Nos. 50-250 and 50-251, Turkey Point Plant Units 3 and 4, Dade County, Florida**

*Date of application for amendments:* October 20, 1994.

*Brief description of amendments:* These amendments relocate the diesel fuel oil testing program requirements to Technical Specifications (TS) Section 6 and to the Bases section of the TS. Also added were actions statements to address diesel fuel oil which does not meet the program limits.

*Date of issuance:* December 28, 1994.

*Effective date:* December 28, 1994.

*Amendment Nos.* 169 and 163.

*Facility Operating Licenses Nos. DPR-31 and DPR-41:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 9, 1994 (59 FR 55870).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated December 28, 1994.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Florida International University, University Park, Miami, Florida 33199.

**Florida Power and Light Company, Docket Nos. 50-250 and 50-251, Turkey Point Plant Units 3 and 4, Dade County, Florida**

*Date of application for amendments:* October 20, 1994.

*Brief description of amendments:* The amendments remove the schedule for

withdrawal of reactor vessel material specimens from the Technical Specifications as discussed in Generic Letter 91-01.

*Date of issuance:* December 28, 1994.

*Effective date:* December 28, 1994.

*Amendment Nos.* 170 and 164.

*Facility Operating Licenses Nos. DPR-31 and DPR-41:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 23, 1994 (59 FR 60381).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated December 28, 1994.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Florida International University, University Park, Miami, Florida 33199.

**Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, City of Dalton, Georgia, Docket Nos. 50-424 and 50-425, Vogtle Electric Generating Plant, Units 1 and 2, Burke County, Georgia**

*Date of application for amendments:* September 13, 1994, as supplemented by letter dated December 6, 1994.

*Brief description of amendments:* The amendments replace Containment Systems Technical Specification (TS) 3.6.2.2 for the Spray Additive System with a new Emergency Core Cooling System (ECCS) TS 3.5.5 for the ECCS Recirculation Fluid pH Control System.

*Date of issuance:* January 5, 1995.

*Effective date:* Phase I to be implemented following Unit 2 Cycle 4 refueling outage; Phase II to be implemented following Unit 1 Cycle 6 refueling outage.

*Amendment Nos.:* 77 and 56 Phase 1; 78 and 57 Phase II.

*Facility Operating License Nos. NPF-68 and NPF-81:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* October 26, 1994 (59 FR 53840). The December 6, 1994, letter provided clarifying information that did not change the initial proposed no significant hazards consideration.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 5, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Burke County Library, 412 Fourth Street, Waynesboro, Georgia 30830.

**GPU Nuclear Corporation, et al., Docket No. 50-219, Oyster Creek Nuclear Generating Station, Ocean County, New Jersey**

*Date of application for amendment:* October 19, 1991, as supplemented March 9, April 27, and December 15, 1994.

*Brief description of amendment:* The amendment establishes additional requirements for the availability of Local Power Range Monitors (LPRMs) associated with the Average Power Range Monitoring (APRM) system. These additional requirements further restrict the allowable number of out of service LPRM/APRM detectors in order to ensure a sufficient response to regional thermal hydraulic oscillations in the reactor core to prevent violation of the Minimum Critical Power Ratio (MCPR) safety limit. The amendment also identifies a lower bound MCPR operating limit for each cycle as identified in the Core Operating Limits Report. This limit shall be greater than or equal to 1.47.

*Date of Issuance:* December 29, 1994.

*Effective date:* As of the date of issuance to be implemented within 30 days.

*Amendment No.:* 176.

*Facility Operating License No. DPR-16.* Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 13, 1991 (56 FR 57697). The March 9, April 27, and December 15, 1994, letters provided clarifying information that did not change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of this amendment is contained in a Safety Evaluation dated December 29, 1994.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Ocean County Library, Reference Department, 101 Washington Street, Toms River, NJ 08753.

**Houston Lighting & Power Company, City Public Service Board of San Antonio, Central Power and Light Company, City of Austin, Texas, Docket Nos. 50-498 and 50-499, South Texas Project, Units 1 and 2, Matagorda County, Texas**

*Date of amendment request:* July 18, 1994.

*Brief description of amendments:* The amendments revised TS Table 4.3-1, Reactor Trip System Instrumentation Surveillance Requirements; TS 3.3.4, Turbine Governor Valves; and TS