

3.7.1.2, Turbine Driven Auxiliary Feedwater Pump, to remove one-time amendments that are no longer necessary. In addition, six minor editorial changes were made.

Date of issuance: December 27, 1994.

Effective date: December 27, 1994, to be implemented within 31 days of issuance.

Amendment Nos.: Unit 1—Amendment No. 67; Unit 2—Amendment No. 56.

Facility Operating License Nos. NPF-76 and NPF-80. The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: August 31, 1994 (59 FR 45024).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated December 27, 1994.

No significant hazards consideration comments received: No

Local Public Document Room location: Wharton County Junior College, J.M. Hodges Learning Center, 911 Boling Highway, Wharton, Texas 77488.

IES Utilities Inc., Docket No. 50-331, Duane Arnold Energy Center, Linn County, Iowa

Date of application for amendment: June 30, 1994, as supplemented November 10, 1994.

Brief description of amendment: The proposed amendment would add Operability Requirements, Limiting Conditions for Operations (LCO) and Surveillance Requirements for the Control Building Chillers.

Date of issuance: December 29, 1994.

Effective date: Date of issuance, to be implemented within 120 days.

Amendment No.: 205.

Facility Operating License No. DPR-49. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: August 3, 1994 (59 FR 39592). The additional information contained in the supplemental letter dated November 10, 1994, was clarifying in nature and did not change the NRC staff's initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated December 29, 1994.

No significant hazards consideration comments received: No.

Local Public Document Room location: Cedar Rapids Public Library, 500 First Street, SE., Cedar Rapids, Iowa 52401.

Indiana Michigan Power Company, Docket Nos. 50-315 and 50-316, Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2, Berrien County, Michigan

Date of application for amendments: November 15, 1993.

Brief description of amendments: The amendments make various administrative and editorial changes to the Technical Specifications.

Date of issuance: December 30, 1994.

Effective date: December 30, 1994.

Amendment Nos.: 186 and 172.

Facility Operating License Nos. DPR-58 and DPR-74. Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: December 22, 1993 (58 FR 67849).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated December 30, 1994.

No significant hazards consideration comments received: No.

Local Public Document Room location: Maud Preston Palenske Memorial Library, 500 Market Street, St. Joseph, Michigan 49085.

Indiana Michigan Power Company, Docket Nos. 50-315 and 50-316, Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2, Berrien County, Michigan

Date of application for amendments: July 19, 1994.

Brief description of amendments: The amendments remove the specific requirements for Types A, B, and C containment leakage rate tests from the Technical Specifications and replace these requirements with a requirement to perform Types A, B, and C testing in accordance with Appendix J to 10 CFR Part 50.

Date of issuance: January 5, 1995.

Effective date: January 5, 1995.

Amendment Nos.: 187/173.

Facility Operating License Nos. DPR-58 and DPR-74. Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: September 28, 1994 (59 FR 49430).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 5, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room location: Maud Preston Palenske Memorial Library, 500 Market Street, St. Joseph, Michigan 49085.

Indiana Michigan Power Company, Docket Nos. 50-315 and 50-316, Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2, Berrien County, Michigan

Date of application for amendments: November 15, 1993, and supplemented October 7, 1994.

Brief description of amendments: The amendments replace the current Technical Specification testing requirements for the Event V reactor coolant system pressure isolation valves with the requirements from ASME Boiler and Pressure Vessel Code, Section XI.

Date of issuance: January 5, 1995.

Effective date: January 5, 1995.

Amendment Nos.: 188/174.

Facility Operating License Nos. DPR-58 and DPR-74. Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: January 5, 1994 (59 FR 623).

At the request of the NRC, the licensee submitted the October 7, 1994, supplement to clarify the new requirements. This supplement did not change the NRC's initial proposed no significant hazards considerations finding; therefore, renoting was not warranted.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 5, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room location: Maud Preston Palenske Memorial Library, 500 Market Street, St. Joseph, Michigan 49085.

Niagara Mohawk Power Corporation, Docket No. 50-220, Nine Mile Point Nuclear Station, Unit 1, Oswego County, New York

Date of application for amendment: August 26, 1994.

Brief description of amendment: The amendment revises Technical Specification 4.3.3.c.(1) to permit a one-time extension of the second 10-year service period for the primary containment integrated leakage rate (Type A) test. The one-time extension permits delaying the third Type A test of the second 10-year service period from the 1995 refueling outage until the 1997 refueling outage. This delay will result in an interval of approximately 46 months between the second and third Type A tests of the second 10-year service period.

Date of issuance: December 29, 1994.

Effective date: As of the date of issuance to be implemented within 30 days.

Amendment No.: 151.