

individual qualifications and the minimum number of SRC members was reduced from 8 to 6.

Date of issuance: December 22, 1994.

Effective date: As of the date of issuance to be implemented within 30 days.

Amendment No.: 156.

Facility Operating License No. DPR-64: Amendment revised the Technical Specifications.

Date of initial notice in Federal

Register: September 30, 1994 (54 FR 50021).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated December 22, 1994.

No significant hazards consideration comments received: No.

Local Public Document Room

location: White Plains Public Library, 100 Martine Avenue, White Plains, New York 10610.

Public Service Electric & Gas Company, Docket Nos. 50-272 and 50-311, Salem Nuclear Generating Station, Unit Nos. 1 and 2, Salem County, New Jersey

Date of application for amendments: September 29, 1994.

Brief description of amendments: The amendments change the Technical Specification surveillance interval for performing an air or smoke flow test through each containment spray header from 5 to 10 years.

Date of issuance: December 27, 1994.

Effective date: December 27, 1994.

Amendment Nos. 163, 144.

Facility Operating License Nos. DPR-70 and DPR-75. The amendments revised the Technical Specifications.

Date of initial notice in Federal

Register: November 23, 1994 (59 FR 60385).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated December 27, 1994.

No significant hazards consideration comments received: No.

Local Public Document Room

location: Salem Free Public Library, 112 West Broadway, Salem, New Jersey 08079.

Southern California Edison Company, et al, Docket No. 50-206, San Onofre Nuclear Generating Station, Unit No. 1, San Diego County, California

Date of application for amendment: April 18, 1994, as supplemented October 26, 1994.

Brief description of amendment: The amendment revises Sections 2.C and 2.D of the San Onofre Nuclear Generating Station, Unit 1 (SONGS 1) Operating License. Section 2.C will be revised to

modify or delete several licensing conditions which either no longer apply or require revision to apply to SONGS 1 in its permanently shutdown and defueled condition. Section 2.D will be revised to exempt Fire Protection reporting from the reporting requirements of Section 2.D.

Date of issuance: December 22, 1994.

Effective date: January 21, 1995.

Amendment No.: 156.

Facility Operating License No. DPR-13: The amendment revised the license conditions.

Date of initial notice in Federal

Register: May 25, 1994 (59 FR 27066).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated December 22, 1994.

No significant hazards consideration comments received: No.

Local Public Document Room

location: Main Library, University of California, P.O. Box 19557, Irvine, California 92713.

Southern Nuclear Operating Company, Inc., Docket Nos. 50-348 and 50-364, Joseph M. Farley Nuclear Plant, Units 1 and 2, Houston County, Alabama.

Date of amendments request: October 20, 1994.

Brief Description of amendments: The amendments delete the requirements for the control room chlorine detection system from the TS and the associated Bases Sections. This request is based on the fact that all stored gaseous chlorine has been removed from the plant site except for containers having an inventory of 150 pounds or less.

Date of issuance: December 28, 1994.

Effective date: December 28, 1994.

Amendment Nos.: 111 and 102.

Facility Operating License Nos. NPF-2 and NPF-8. Amendments revise the Technical Specifications.

Date of initial notice in Federal

Register: November 23, 1994 (59 FR 60386).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated December 28, 1994.

No significant hazards consideration comments received: No.

Local Public Document Room

location: Houston-Love Memorial Library, 212 W. Burdeshaw Street, Post Office Box 1369, Dothan, Alabama 36302.

Tennessee Valley Authority, Docket Nos. 50-327 and 50-328, Sequoyah Nuclear Plant, Units 1 and 2, Hamilton County, Tennessee

Date of application for amendments: September 9, 1994 (TS 94-04).

Brief description of amendments: The amendments revise the technical specifications related to the cold leg injection accumulators.

Date of issuance: December 27, 1994.

Effective date: December 27, 1994.

Amendment Nos.: 192 and 184.

Facility Operating License Nos. DPR-77 and DPR-79: Amendments revise the technical specifications.

Date of initial notice in Federal

Register: October 12, 1994 (59 FR 51629).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated December 27, 1994.

No significant hazards consideration comments received: None.

Local Public Document Room

location: Chattanooga-Hamilton County Library, 1101 Broad Street, Chattanooga, Tennessee 37402.

Tennessee Valley Authority, Docket Nos. 50-327, Sequoyah Nuclear Plant, Units 1, Hamilton County, Tennessee

Date of application for amendment: November 2, 1994 (TS 94-17).

Brief description of amendment: The amendment adds Operating License Condition 2.C.(25) to provide a limited extension of the surveillance test intervals for certain specified instrumentation on Unit 1 to coincide with the Cycle 7 refueling outage. The surveillance intervals that are affected are specified in the attached safety evaluation and are for tests that would be extended to October 1, 1995, and would result in extension of the specified 18-, 36- and 54-month surveillances to 29.5, 48 and 71.5 months, respectively.

Date of issuance: January 3, 1995.

Effective date: January 3, 1995.

Amendment No.: 193.

Facility Operating License Nos. DPR-77: Amendment revises the operating license.

Date of initial notice in Federal

Register: November 23, 1994 (59 FR 60387).

The Commission's related evaluation of the change to the operating license is contained in a Safety Evaluation dated January 3, 1995.

No significant hazards consideration comments received: None.

Local Public Document Room

location: Chattanooga-Hamilton County Library, 1101 Broad Street, Chattanooga, Tennessee 37402

Virginia Electric and Power Company, Docket Nos. 50-280 and 50-281, Surry Power Station, Unit Nos. 1 and 2, Surry County, Virginia

Date of application for amendments: October 11, 1994.