

recommendations for Emergency Diesel Generator (EDG) Surveillance Requirements in NUREG-1366, and regulatory guidance provided in Generic Letter (GL) 93-05 and GL 94-01. This issuance also contains FPL's commitment to implement a maintenance program for monitoring and maintaining EDG performance for both St. Lucie Units consistent with 10 CFR 50.65 and the guidance of Regulatory Guide 1.160.

*Date of Issuance:* June 29, 1995

*Effective Date:* June 29, 1995

*Amendment Nos.:* 138 and 78

*Facility Operating License Nos.* DPR-67 and NPF-16: Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* May 10, 1995 (60 FR 24910) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 29, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room location:* Indian River Junior College Library, 3209 Virginia Avenue, Fort Pierce, Florida 34954-9003.

**Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, City of Dalton, Georgia, Docket Nos. 50-424 and 50-425, Vogtle Electric Generating Plant, Units 1 and 2, Burke County, Georgia**

*Date of application for amendments:* November 19, 1995

*Brief description of amendments:* The amendments relocate the requirements of Technical Specification 3/4.3.4, Turbine Overspeed Protection, to Section 16.3 of the Vogtle Final Safety Analysis Report (FSAR). In addition, the surveillance intervals for exercising the high pressure turbine stop valves, the low pressure turbine intermediate stop valves and intercept valves, and the high pressure turbine control valves are extended after relocation to the FSAR.

*Date of issuance:* July 3, 1995

*Effective date:* As of the date of issuance to be implemented within 30 days.

*Amendment Nos.:* 88 and 66

*Facility Operating License Nos.* NPF-68 and NPF-81: Amendments revised the technical Specifications.

*Date of initial notice in Federal Register:* February 16, 1994 (59 FR 7689) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 3, 1995. No significant hazards consideration comments received: No

*Local Public Document Room location:* Burke County Library, 412 Fourth Street, Waynesboro, Georgia 30830.

**Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, City of Dalton, Georgia, Docket Nos. 50-424 and 50-425, Vogtle Electric Generating Plant, Units 1 and 2, Burke County, Georgia**

*Date of application for amendments:* December 27, 1994

*Brief description of amendments:* The amendments revise the frequency of conducting leak testing of containment purge valves with seals made of resilient material from every 3 months to each refueling outage.

*Date of issuance:* July 7, 1995

*Effective date:* As of the date of issuance to be implemented within 30 days.

*Amendment Nos.:* 89 and 67

*Facility Operating License Nos.* NPF-68 and NPF-81: Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* February 1, 1995 (60 FR 6301) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 7, 1995. No significant hazards consideration comments received: No

*Local Public Document Room location:* Burke County Library, 412 Fourth Street, Waynesboro, Georgia 30830.

**Houston Lighting & Power Company, City Public Service Board of San Antonio, Central Power and Light Company, City of Austin, Texas, Docket Nos. 50-498 and 50-499, South Texas Project, Units 1 and 2, Matagorda County, Texas**

*Date of amendment request:* February 15, 1995.

*Brief description of amendments:* The amendments modified (by relocation to the Technical Requirements Manual) Technical Specification (TS) 3/4.3.3.7, Chemical Detection Systems, and TS 3/4.8.4.1, Electrical Equipment Protective Devices - Containment Penetration Conductor Overcurrent Protective Devices, and the associated Bases.

*Date of issuance:* July 6, 1995

*Effective date:* July 6, 1995, to be implemented within 30 days.

*Amendment Nos.:* Unit 1 - Amendment No. 76; Unit 2 - Amendment No. 65

*Facility Operating License Nos.* NPF-76 and NPF-80. The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* March 29, 1995 (60 FR 16189) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 6, 1995. No significant hazards consideration comments received: No

*Local Public Document Room location:* Wharton County Junior College, J. M. Hodges Learning Center, 911 Boling Highway, Wharton, TX 77488.

**IES Utilities Inc., Docket No. 50-331, Duane Arnold Energy, Center, Linn County, Iowa**

*Date of application for amendment:* March 28, 1995

*Brief description of amendment:* The amendment revises Technical Specifications (TS) Table 3.2-A by clarifying or correcting entries to the table. The amendment also revises the TS Bases to describe more clearly the logic arrangements in Table 3.2-A.

*Date of issuance:* June 14, 1995

*Effective date:* June 14, 1995

*Amendment No.:* 212

*Facility Operating License No.* DPR-49. Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* April 26, 1995 (60 FR 20519) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 14, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room location:* Cedar Rapids Public Library, 500 First Street, S. E., Cedar Rapids, Iowa 52401.

**Indiana Michigan Power Company, Docket Nos. 50-315 and 50-316, Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2, Berrien County, Michigan**

*Date of application for amendments:* March 31, 1995

*Brief description of amendments:* The amendments modify the Containment Ventilation System Technical Specifications (and associated Bases) to allow limited containment purge operation in Modes 1, 2, 3, and 4 for pressure control, ALARA [as low as is reasonably achievable], and respirable air quality considerations.

*Date of issuance:* June 23, 1995

*Effective date:* June 23, 1995

*Amendment Nos.:* 195 and 181

*Facility Operating License Nos.* DPR-58 and DPR-74. Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* April 26, 1995 (60 FR 20520) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 23, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room location:* Maud Preston Palenske Memorial Library, 500 Market Street, St. Joseph, Michigan 49085.