

**Indiana Michigan Power Company,  
Docket No. 50-315, Donald C. Cook,  
Nuclear Plant, Unit No. 1, Berrien  
County, Michigan**

*Date of application for amendment:* March 17, 1995

*Brief description of amendment:* The amendment allows a one-time extension of the required test interval for the overall integrated containment leak rate test (Type A test). This extension allows the third Type A test of the second 10-year service period to be performed during the refueling outage that will follow the end of Cycle 15.

Concurrently, the Commission has also granted a one-time scheduler exemption to allow an extension of one cycle for the performance of the 10 CFR Part 50, Appendix J, Type A test.

*Date of issuance:* July 6, 1995

*Effective date:* July 6, 1995

*Amendment No.:* 196

*Facility Operating License No.* DPR-58. Amendment revises the Technical Specifications.

*Date of initial notice in Federal Register:* April 26, 1995 (60 FR 20519) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 6, 1995. No significant hazards consideration comments received: No. Local Public

*Document Room location:* Maud Preston Palenske Memorial Library, 500 Market Street, St. Joseph, Michigan 49085.

**Northern States Power Company,  
Docket Nos. 50-282 and 50-306, Prairie  
Island Nuclear Generating Plant, Unit  
Nos. 1 and 2, Goodhue County,  
Minnesota**

*Date of application for amendments:* December 5, 1994, as supplemented January 9, 1995 and May 15, 1995.

*Date of application for amendments:* The amendments revise the Prairie Island Technical Specifications to allow containment airlock doors to remain open during core alterations provided certain conditions are met. In its May 15, 1995, letter, the licensee withdrew the portion of its original application which dealt with containment penetrations during core alterations. The staff granted the licensee's request to withdraw all aspects of its application concerning the opening of containment penetrations during core alterations.

*Date of issuance:* July 3, 1995

*Effective date:* July 3, 1995

*Amendment Nos.:* 119/112

*Facility Operating License Nos.* DPR-42 and DPR-60. Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* February 1, 1995 (60 FR 6306).

The January 9 and May 15, 1995, letters provided updated Technical Specification pages and clarifying information in response to discussions with the staff during various teleconferences conducted during the review process. This information was within the scope of the original application and did not change the staff's initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 3, 1995. No Significant hazards consideration comments received: No.

*Local Public Document Room location:* Minneapolis Public Library, Technology and Science Department, 300 Nicollet Mall, Minneapolis, Minnesota 55401.

**Omaha Public Power District, Docket  
No. 50-285, Fort Calhoun Station, Unit  
No. 1, Washington County, Nebraska**

*Date of amendment request:* February 10, 1995

*Brief description of amendment:* The amendment relocates the requirements for the incore instrumentation (ICI) system from the technical specifications to the Updated Safety Analysis Report (USAR).

*Date of issuance:* June 26, 1995

*Effective date:* June 26, 1995

*Amendment No.:* 167

*Facility Operating License No.* DPR-40. The amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* March 15, 1995 (60 FR 14025) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 26, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room location:* W. Dale Clark Library, 215 South 15th Street, Omaha, Nebraska 68102.

**Pacific Gas and Electric Company,  
Docket Nos. 50-275 and 50-323, Diablo  
Canyon Nuclear Power Plant, Unit Nos.  
1 and 2, San Luis Obispo County,  
California**

*Date of application for amendments:* April 19, 1995 (LAR 95-03)

*Brief description of amendments:* The amendments would allow an emergency diesel generator (EDG) hot restart test within 5 minutes of a 2-hour run at the continuous rating instead of an EDG loss of offsite power load sequencing test within 5 minutes of the 24-hour endurance run.

*Date of issuance:* June 26, 1995

*Effective date:* June 26, 1995

*Amendment Nos.:* Unit 1 - Amendment No. 105; Unit 2 - Amendment No. 104

*Facility Operating License Nos.* DPR-80 and DPR-82: The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* May 23, 1995 (60 FR 27340) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 26, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room location:* California Polytechnic State University, Robert E. Kennedy Library, Government Documents and Maps Department, San Luis Obispo, California 93407.

**Pacific Gas and Electric Company,  
Docket Nos. 50-275 and 50-323, Diablo  
Canyon Nuclear Power Plant, Unit Nos.  
1 and 2, San Luis Obispo County,  
California**

*Date of application for amendments:* February 16, 1994, as supplemented by letter dated April 25, 1995 (Reference LAR 94-05)

*Brief description of amendments:* The amendment revises Technical Specifications 3/4.7.2, "Steam Generator Pressure/Temperature Limitation," 3/4.7.7, "Snubbers," 3/4.7.8, "Sealed Source Contamination," 3/4.7.11, "Area Temperature Monitoring," and 3/4.7.13, "Flood Protection," in accordance with the Commission's final policy statement for relocation of current technical specifications to licensee controlled documents that do not satisfy any of the policy statement criteria.

*Date of issuance:* July 6, 1995

*Effective date:* July 6, 1995

*Amendment Nos.:* Unit 1 - Amendment No. 106; Unit 2 - Amendment No. 105

*Facility Operating License Nos.* NPF-10 and NPF-15: The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* April 13, 1994 (59 FR 17603) The April 25, 1995, supplemental letter provided additional clarifying information and did not change the initial no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 6, 1995. No significant hazards consideration comments received: No.

*Local Public Document Room location:* California Polytechnic State University, Robert E. Kennedy Library, Government Documents and Maps Department, San Luis Obispo, California 93407.