

**Power Authority of the State of New York, Docket No. 50-333, James A. FitzPatrick Nuclear Power Plant, Oswego County, New York**

*Date of application for amendment:* February 22, 1995

*Brief description of amendment:* The amendment modifies operability and surveillance requirements for the reactor vessel overfill protection instrumentation that initiates feedwater pump turbine and main turbine trips on high reactor vessel water level. The NRC staff has determined that the proposed Technical Specification (TS) changes will have no adverse impact on plant safety and will enhance the current TSs by adding operability requirements for the reactor vessel overfill protection system. Therefore, the proposed TS changes are acceptable.

*Date of issuance:* June 19, 1995

*Effective date:* As of the date of issuance to be implemented within 30 days.

*Amendment No.:* 225

*Facility Operating License No.* DPR-59: Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* May 10, 1995 (60 FR 24915) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 19, 1995. No significant hazards consideration comments received: No Local Public Document Room location: Reference and Documents Department, Penfield Library, State University of New York, Oswego, New York 13126.

**Public Service Electric & Gas Company, Docket No. 50-354, Hope Creek Generating Station, Salem County, New Jersey**

*Date of application for amendment:* July 28, 1994 and December 15, 1994

*Brief description of amendment:* This amendment makes changes to TS Section 3/4.8.1 "AC SOURCES." The staff found it appropriate to combine these two applications into one amendment. The amendment removes the surveillance requirements, methodology and frequency for Emergency Diesel Generator (EDG) fuel oil from the TS and relocates them in a controlled plant procedure, VSH.SS-CA.ZZ-0013(Q) "Procedures for Testing Diesel Fuel and Fuel Oil at Artificial Island for PSE&G Nuclear Operations." The changes also delete an unnecessary lab test for the fuel oil and extend the surveillance frequency from once per 92 days to once per 184 days. In addition and in accordance with 10 CFR 50.90, this amendment removes TS Surveillance Requirement 4.8.1.1.2.h.1

in order that PSE&G can utilize plant-controlled programs to govern diesel generator maintenance. To ensure procedural consistency and reduce the impact of this change on Hope Creek procedures, the remaining Surveillance Requirements of TS 4.8.1.1.2.h are not renumbered.

*Date of issuance:* June 29, 1995

*Effective date:* June 29, 1995

*Amendment No.:* 74

*Facility Operating License No.* NPF-57: This amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* August 31, 1994 (59 FR 45034) and April 26, 1995 (60 FR 20526) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 29, 1995. No significant hazards consideration comments received: No

*Local Public Document Room*

*location:* Pennsville Public Library, 190 S. Broadway, Pennsville, New Jersey 08070.

**Public Service Electric & Gas Company, Docket No. 50-272, Salem Nuclear Generating Station, Unit No. 1, Salem County, New Jersey Date of application for amendment: April 4, 1995**

*Brief description of amendment:* The amendment allows a one-time interval extension for the Type A test required by 10 CFR Part 50, Appendix J. Instead of conducting the test during the twelfth refueling outage, it can now be conducted during the thirteenth refueling outage, but no later than June 1997.

*Date of issuance:* July 5, 1995

*Effective date:* July 5, 1995

*Amendment No.:* 171

*Facility Operating License No.* DPR-70: This amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* May 23, 1995 (60 FR 27341) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 5, 1995. No significant hazards consideration comments received: No

*Local Public Document Room*

*location:* Salem Free Public Library, 112 West Broadway, Salem, New Jersey 08079.

**Tennessee Valley Authority, Docket Nos. 50-327 and 50-328, Sequoyah Nuclear Plant, Units 1 and 2, Hamilton County, Tennessee**

*Date of application for amendments:* April 6, 1995; supplemented May 26, 1995 (TS 94-19)

*Brief description of amendments:* The amendments revise action statements to eliminate starting of emergency diesel

generators in order to verify their operability whenever one of the required electrical power sources is inoperable or a diesel is inoperable unless the diesel inoperability is due to a common cause failure.

*Date of issuance:* June 29, 1995

*Effective date:* June 29, 1995

*Amendment Nos.:* 205 and 195

*Facility Operating License Nos.* DPR-77 and DPR-79: Amendments revise the technical specifications.

*Date of initial notice in Federal Register:* April 26, 1995 (60 FR 20529) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 29, 1995. No significant hazards consideration comments received: None

*Local Public Document Room*

*location:* Chattanooga-Hamilton County Library, 1101 Broad Street, Chattanooga, Tennessee 37402.

**The Cleveland Electric Illuminating Company, Centerior Service Company, Duquesne Light Company, Ohio Edison Company, Pennsylvania Power Company, Toledo Edison Company, Docket No. 50-440, Perry Nuclear Power Plant, Unit No. 1, Lake County, Ohio Date of application for amendment: September 27, 1993 and December 16, 1994**

*Brief description of amendment:* The amendment revised the Technical Specification Section 6.8.1, "Unit Staff Qualifications," to make it consistent with the current requirements of Part 55 of Title 10 of the Code of Federal Regulations.

*Date of issuance:* June 27, 1995

*Effective date:* June 27, 1995

*Amendment No.:* 70

*Facility Operating License No.* NPF-58: This amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* December 8, 1993 (58 FR 64604) and February 1, 1995 (60 FR 6310). The Commission's related evaluation of the amendment is contained in an Environmental Assessment dated February 28, 1995, and a Safety Evaluation, dated June 27, 1995. No significant hazards consideration comments received: No

*Local Public Document Room*

*location:* Perry Public Library, 3753 Main Street, Perry, Ohio 44081.

**Union Electric Company, Docket No. 50-483, Callaway Plant, Unit 1, Callaway County, Missouri**

*Date of application for amendment:* July 16, 1993

*Brief description of amendment:* The amendment revises the Technical Specifications (TS) 3/4.8.1.1 and 3/