

same as above. They were published as individual notices either because time did not allow the Commission to wait for this biweekly notice or because the action involved exigent circumstances. They are repeated here because the biweekly notice lists all amendments issued or proposed to be issued involving no significant hazards consideration.

For details, see the individual notice in the **Federal Register** on the day and page cited. This notice does not extend the notice period of the original notice.

Commonwealth Edison Company, Docket Nos. 50-254 and 50-265, Quad Cities Nuclear Power Station, Units 1 and 2, Rock Island County, Illinois

Date of amendment request: February 23, 1995

Description of amendment request: The amendment relates to Commonwealth Edison Company's (ComEd) request to reflect the merger between IIGEC, MidAmerican, Midwest Power Systems Inc., and Midwest Resources, Inc. By letter dated November 21, 1994, Iowa-Illinois Gas and Electric Company (IIGEC) requested approval, pursuant to Section 50.80 of Title 10 of the Code of Federal Regulations, of the transfer of its ownership share of 25 percent of Quad Cities Nuclear Power Station, Units 1 and 2, to MidAmerican Energy Company (MidAmerican).

Date of publication of individual notice in Federal Register: July 5, 1995 (60 FR 35054)

Expiration date of individual notice: August 4, 1995

Local Public Document Room location: Dixon Public Library, 221 Hennepin Avenue, Dixon, Illinois 61021.

Connecticut Yankee Atomic Power Company, Docket No. 50-213, Haddam Neck Plant, Middlesex County, Connecticut

Date of amendment request: March 31, 1995

Description of amendment request: The proposed amendment will delete Technical Specification (TS) Sections 1.38 and 1.39, "Definitions, Fuel Assembly Types," revise TS Sections 3/4.9.3, "Refueling Operations, Decay Time" and TS 3/4.9.14, "Refueling Operations, Spent Fuel Pool - Reactivity Condition," replace TS Sections 5.6.1.1, "Spent Fuel," and TS 5.6.3, "Capacity," and add a new TS Section 3/4.9.15, "Refueling Operations, Spent Fuel Pool Cooling." These changes would support a rerack of the spent fuel pool to expand the spent fuel pool's storage capacity from 1168 assemblies to 1480

assemblies so as to accommodate a full-core-discharge through the current validity date of the Haddam Neck operating license (2007).

Date of publication of individual notice in Federal Register: May 12, 1995 (60 FR 25746)

Expiration date of individual notice: June 12, 1995

Local Public Document Room location: Russell Library, 123 Broad Street, Middletown, CT 06457.

Notice Of Issuance Of Amendments To Facility Operating Licenses

During the period since publication of the last biweekly notice, the Commission has issued the following amendments. The Commission has determined for each of these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for A Hearing in connection with these actions was published in the **Federal Register** as indicated.

Unless otherwise indicated, the Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments. If the Commission has prepared an environmental assessment under the special circumstances provision in 10 CFR 51.12(b) and has made a determination based on that assessment, it is so indicated.

For further details with respect to the action see (1) the applications for amendment, (2) the amendment, and (3) the Commission's related letter, Safety Evaluation and/or Environmental Assessment as indicated. All of these items are available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document rooms for the particular facilities involved.

Commonwealth Edison Company, Docket Nos. 50-295 and 50-304, Zion Nuclear Power Station Units 1 and 2, Lake County, Illinois

Date of application for amendments: June 14, 1995

Brief description of amendments: The amendments revise the requirement to perform an emergency diesel generator (EDG) automatic start and sequence loading test immediately following the 24 hour EDG endurance test.

Date of issuance: July 18, 1995

Effective date: July 18, 1995

Amendment Nos.: 166 and 154

Facility Operating License Nos. DPR-39 and DPR-48: The amendments revised the Technical Specifications. Public comments requested as to proposed no significant hazards consideration determination: Yes (60 FR 34308). This notice provided an opportunity to submit comments on the Commission's proposed no significant hazards consideration determination. No comments have been received. The notice also provided for an opportunity to request a hearing by July 31, 1995, but indicated that if the Commission makes a final no significant hazards consideration determination any such hearing would take place after issuance of the amendment. The Commission's related evaluation of the amendments, finding of exigent circumstances and final no significant hazards consideration determination is contained in a Safety Evaluation dated July 18, 1995.

Local Public Document Room location: Waukegan Public Library, 128 N. County Street, Waukegan, Illinois 60085.

Indiana Michigan Power Company, Docket Nos. 50-315 and 50-316, Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2, Berrien County, Michigan

Date of application for amendments: March 31, 1995

Brief description of amendments: The amendments revise Technical Specification section 3.9.4 to allow, under certain conditions, both containment personnel airlocks to be open during core alterations.

Date of issuance: July 12, 1995

Effective date: July 12, 1995

Amendment Nos.: 197 and 182

Facility Operating License Nos. DPR-58 and DPR-74. Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: June 6, 1995 (60 FR 29879) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 12, 1995. No significant hazards consideration comments received: No.