

Local Public Document Room
location: Maud Preston Palenske
 Memorial Library, 500 Market Street, St.
 Joseph, Michigan 49085.

**Nebraska Public Power District, Docket
 No. 50-298, Cooper Nuclear
 Station, Nemaha County, Nebraska**

Date of amendment request: May 2,
 1995

Brief description of amendment: The
 amendment revised Surveillance
 Requirement 4.7.A.2.f.1 to allow a one-
 time extension for the performance of
 Type B local leak rate testing of the
 drywell head and manport from July 17,
 1995, until startup from Refueling
 Outage 16, scheduled to commence on
 October 13, 1995.

Date of issuance: July 11, 1995

Effective date: July 11, 1995

Amendment No.: 170

Facility Operating License No. DPR-
 46. Amendment revised the Technical
 Specifications.

*Date of initial notice in Federal
 Register:* June 6, 1995 (60 FR 29879) The
 Commission's related evaluation of the
 amendment is contained in a Safety
 Evaluation dated July 11, 1995 No
 significant hazards consideration
 comments received: No.

Local Public Document Room
location: Auburn Public Library, 118
 15th Street, Auburn, NE 68305.

**Northeast Nuclear Energy Company, et
 al., Docket No. 50-423,
 Millstone Nuclear Power Station, Unit
 No. 3, New London County, Connecticut**

Date of application for amendment:
 January 10, 1995

Brief description of amendment: The
 amendment revises the Technical
 Specifications to delete the power range
 negative flux trip from Tables 2.2-1, 3.3-
 1, and 4.3-1, and delete the associated
 Bases Section 2.0.

Date of issuance: July 11, 1995

Effective date: As of the date of
 issuance to be implemented within 30
 days.

Amendment No.: 116

Facility Operating License No. NPF-
 49. Amendment revised the Technical
 Specifications.

*Date of initial notice in Federal
 Register:* March 1, 1995 (60 FR
 11135) The Commission's related
 evaluation of the amendment is
 contained in a Safety Evaluation dated
 July 11, 1995. No significant hazards
 consideration comments received: No.

Local Public Document Room
location: Learning Resources Center,
 Three Rivers Community-Technical
 College, 574 New London Turnpike,
 Norwich, CT 06360.

**Northeast Nuclear Energy Company, et
 al., Docket No. 50-423,
 Millstone Nuclear Power Station, Unit
 No. 3, New London County, Connecticut**

Date of application for amendment:
 March 29, 1995

Brief description of amendment: The
 amendment revises Technical
 Specification 3.10.5 to allow more than
 one control bank to be fully withdrawn
 from the core simultaneously in order to
 conduct rod drop time response testing.

Date of issuance: July 11, 1995

Effective date: As of the date of
 issuance to be implemented within 60
 days.

Amendment No.: 117

Facility Operating License No. NPF-
 49. Amendment revised the Technical
 Specifications.

*Date of initial notice in Federal
 Register:* June 6, 1995 (60 FR 29880)
 The Commission's related evaluation of
 the amendment is contained in a Safety
 Evaluation dated July 11, 1995. No
 significant hazards consideration
 comments received: No.

Local Public Document Room
location: Learning Resources Center,
 Three Rivers Community-Technical
 College, 574 New London Turnpike,
 Norwich, CT 06360.

**Northern States Power Company,
 Docket No. 50-263, Monticello
 Nuclear Generating Plant, Wright
 County, Minnesota**

Date of application for amendment:
 February 12, 1993, as supplemented by
 letters dated March 22, 1993, and
 August 25, 1994

Brief description of amendment: The
 amendment increases the minimum
 core spray pump flow to more
 conservatively account for emergency
 core cooling systems bypass leakage
 paths. The amendment also makes
 various typographical, editorial and
 administrative corrections and changes.

Date of issuance: July 12, 1995

Effective date: July 12, 1995

Amendment No.: 93

Facility Operating License No. DPR-
 22. Amendment revised the Technical
 Specifications.

*Date of initial notice in Federal
 Register:* August 4, 1993 (58 FR 41508).
 The August 25, 1994 letter provided
 clarifying information within the scope
 of the original submittal and did not
 change the staff's initial proposed no
 significant hazards considerations
 determination. The Commission's
 related evaluation of the amendment is
 contained in a Safety Evaluation dated
 July 12, 1995. No significant hazards
 consideration comments received: No.

Local Public Document Room
location: Minneapolis Public Library,

Technology and Science Department,
 300 Nicollet Mall, Minneapolis,
 Minnesota 55401.

**Omaha Public Power District, Docket
 No. 50-285, Fort Calhoun Station, Unit
 No. 1, Washington County, Nebraska**

Date of amendment request:

November 11, 1994, as supplemented by
 letters dated April 7, 1995, and June 26,
 1995

Brief description of amendment: The
 amendment implements administrative
 changes to TS 5.2 and 5.5. These
 changes reflect organizational changes
 in OPPD senior management, delete
 specific titles of personnel on the Plant
 Review Committee (PRC), revise the
 makeup of the PRC quorum, revise the
 membership of the Senior Audit and
 Review Committee (SARC), delete SARC
 audit frequencies and add minor
 clarifications to the descriptions of
 SARC reviews and audits.

Date of issuance: July 21, 1995

Effective date: July 21, 1995

Amendment No.: 168

Facility Operating License No. DPR-
 40. Amendment revised the
 Technical Specifications.

*Date of initial notice in Federal
 Register:* December 21, 1994 (59 FR
 65819). The April 7, 1995, and June 26,
 1995, letters provided clarifying
 information and did not change the
 initial no significant hazards
 consideration determination. The
 Commission's related evaluation of the
 amendment is contained in a Safety
 Evaluation dated July 21, 1995. No
 significant hazards consideration
 comments received: No.

Local Public Document Room
location: W. Dale Clark Library, 215
 South 15th Street, Omaha, Nebraska
 68102.

**Omaha Public Power District, Docket
 No. 50-285, Fort Calhoun Station, Unit
 No. 1, Washington County, Nebraska**

Date of amendment request: March 1,
 1995

Brief description of amendment: The
 amendment revises TS 2.5, 2.8, 2.11,
 3.2, and 3.10 and relocates
 administrative controls for the
 emergency and security plans from TS
 5.5 and 5.8 to the plans. The relocation
 is in accordance with Generic Letter
 (GL) 93-07, "Modification of the
 Technical Specification Administrative
 Control Requirements for Emergency
 and Security Plans."

Date of issuance: July 21, 1995

Effective date: July 21, 1995

Amendment No.: 169

Facility Operating License No. DPR-
 40: The amendment revised the
 Technical Specifications.