

Date of initial notice in Federal Register: April 12, 1995 (60 FR 18627) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 21, 1995. No significant hazards consideration comments received: No.

Local Public Document Room location: W. Dale Clark Library, 215 South 15th Street, Omaha, Nebraska 68102.

Pacific Gas and Electric Company, Docket No. 50-133, Humboldt Bay Power Plant, Unit 3, Humboldt County, California

Date of application for amendment: April 10, 1995

Brief description of amendment: This amendment revised License No. DPR-7, to permit the provisions of 10 CFR 50.59 to be applied with respect to changes to the facility or procedures described in the Decommissioning Plan or changes to the Decommissioning Plan, and the conduct of tests or experiments not described in the Decommissioning Plan.

Date of issuance: July 7, 1995

Effective date: This license amendment is effective as of the date of its issuance and must be fully implemented no later than 30 days from the date of issuance.

Amendment No.: 29 Facility License No. DPR-7: This amendment revised License No. DPR-7

Date of initial notice in Federal Register: June 6, 1995 (60 FR 29885) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 7, 1995. No significant hazards consideration comments received: No

Local Public Document Room location: Humboldt County Library, 636 F Street, Eureka, California 95501.

PECO Energy Company, Public Service Electric and Gas Company, Delmarva Power and Light Company, and Atlantic City Electric Company, Docket No. 50-278, Peach Bottom Atomic Power Station, Unit No. 3, York County, Pennsylvania

Date of application for amendment: November 21, 1994

Brief description of amendment: This amendment changes the technical specifications (TS) by allowing the third Type A Containment Integrated Leakage Rate Test in the second 10-year service period to be conducted during refueling outage 11 scheduled for September 1997. This TS change is consistent with a one-time exemption from Appendix J to 10 CFR Part 50 that extends the 10-year service period and allows the three type A tests to be performed at intervals that are not approximately equal.

Date of issuance: July 10, 1995

Effective date: July 10, 1995

Amendment No.: 210

Facility Operating License No. DPR-56: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: May 23, 1995 (60 FR 27340) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 10, 1995. No significant hazards consideration comments received: No

Local Public Document Room location: Government Publications Section, State Library of Pennsylvania, (REGIONAL DEPOSITORY) Education Building, Walnut Street and Commonwealth Avenue, Box 1601, Harrisburg, Pennsylvania 17105.

PECO Energy Company, Public Service Electric and Gas Company, Delmarva Power and Light Company, and Atlantic City Electric Company, Docket No. 50-278, Peach Bottom Atomic Power Station, Unit No. 3, York County, Pennsylvania

Date of application for amendment: June 23, 1993, as supplemented by letters dated April 5, May 2, June 6, June 8, July 6 (two letters), July 7, July 20, July 28 (two letters), September 16, September 30, and October 14, 1994 and June 22, 1995.

Brief description of amendment: The amendment raises the authorized maximum power level from 3293 MWt to a new limit of 3458 MWt. The amendment also approves changes to the Technical Specifications to implement operation at the increased power limit.

Date of issuance: July 18, 1995

Effective date: As of date of issuance and is to be implemented prior to startup in Cycle 11, currently scheduled for October 1995.

Amendment No.: 211

Facility Operating License No. DPR-56: Amendment revised the License and the Technical Specifications.

Date of initial notice in Federal Register: August 29, 1994 (59 FR 44432) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 18, 1995. No significant hazards consideration comments received: No

Local Public Document Room location: Government Publications Section, State Library of Pennsylvania, (REGIONAL DEPOSITORY) Education Building, Walnut Street and Commonwealth Avenue, Box 1601, Harrisburg, Pennsylvania 17105.

Pennsylvania Power and Light Company, Docket Nos. 50-387 and 50-388 Susquehanna Steam Electric Station, Units 1 and 2, Luzerne County, Pennsylvania

Date of application for amendments: April 10, 1995

Brief description of amendments: Remove the response time limit Tables 3.3.1-2, 3.3.2-3, and 3.3.3-3 from the Technical Specifications, and add the information to the Final Safety Analysis Report in accordance with Generic Letter 93-08.

Date of issuance: July 11, 1995

Effective date: July 11, 1995

Amendment Nos.: 148 and 118

Facility Operating License Nos. NPF-14 and NPF-22. The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: June 6, 1995 (60 FR 29887) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 11, 1995. No significant hazards consideration comments received: No

Local Public Document Room location: Osterhout Free Library, Reference Department, 71 South Franklin Street, Wilkes-Barre, Pennsylvania 18701.

Philadelphia Electric Company, Docket Nos. 50-352 and 50-353, Limerick Generating Station, Units 1 and 2, Montgomery County, Pennsylvania

Date of application for amendments: November 21, 1994, as supplemented April 6, and July 3, 1995

Brief description of amendments: These amendments make changes affecting the Administrative Controls Section of the Technical Specifications. The areas changed are Nuclear Effectiveness and Efficiency Design Study (NEEDS) Organization Title Changes; Minimum Shift Crew Composition; delete Independent Technical Review Section from TS; delete Nuclear Review Board (NRB) Review Section from TS; and delete NRB Audit Section from TS.

Date of issuance: July 18, 1995

Effective date: Units 1 and 2, as of the date of issuance and shall be implemented within 30 days.

Amendment Nos.: 96 and 60

Facility Operating License Nos. NPF-39 and NPF-85. The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: May 10, 1995 (60 FR 24914) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 18, 1995. No significant hazards consideration comments received: No