Effective date: July 14, 1995, to be implemented within 30 days of the date of issuance.

Amendment Nos.: Unit 2 -Amendment No. 120; Unit 3 -Amendment No. 109

Facility Operating License Nos. NPF-10 and NPF-15: The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: September 29, 1993 (58 FR 50975). The September 6, 1994, supplemental letter provided additional clarifying information and did not change the initial no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 14, 1995. No significant hazards consideration comments received: No

Local Public Document Room location: Main Library, University of California, P.O. Box 19557,Irvine, California 92713.

Southern California Edison Company, et al., Docket Nos. 50-361 and 50-362, San Onofre Nuclear Generating Station, Unit Nos. 2 and 3, San Diego County, California

Date of application for amendments: September 3, 1992

Brief description of amendments: These amendments revise TS 3/4.4.8 "Pressure/Temperature Limits - Reactor Coolant System," and their associated Bases, following NRC guidance provided in Generic Letter 91-01. 'Removal of the Schedule for Withdrawal of Reactor Vessel Material Specimens from Technical Specifications." This generic letter allows licensees to remove the reactor vessel material surveillance capsule withdrawal schedules from the TS because they are a duplication of the requirements of 10 CFR Part 50 Appendix H.

Date of issuance: July 17, 1995 Effective date: July 17, 1995, to be implemented within 30 days of issuance Amendment Nos.: Unit 2 -

Amendment No. 121; Unit 3 - Amendment No. 110

Facility Operating License Nos. NPF-10 and NPF-15: The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: February 17, 1993 (58 FR 8781)The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 17, 1995.No significant hazards consideration comments received: No

Local Public Document Room location: Main Library, University of California, P. O. Box 19557, Irvine, California 92713. Southern California Edison Company, et al., Docket Nos. 50-361 and 50-362, San Onofre Nuclear Generating Station, Unit Nos. 2 and 3, San Diego County, California

Date of application for amendments: April 30, 1993, as supplemented by letters dated July 6, 1994 (separate letters for each unit), and letter dated January 27, 1995.

Brief description of amendments: These amendments revise TS 3/4.4.8.1, "Pressure-Temperature Limits," TS 3.4.8.3.1, "Overpressure Protection Systems-RCS Temperature less than or equal to °F [for Unit 2, less than or equal to 246°F for Unit 3]," TS 3.4.8.3.2, "Overpressure Protection Systems-RCS Temperature ≤256°F [for Unit 2, ≤246°F for Unit 3]," and the associated TS Bases. The proposed change (1) revises the reactor coolant system (RCS) pressure-temperature (P-T) limits and the low temperature overpressure protection (LTOP) enable temperatures to be effective until 20 effective full power years (EFPY) of operation and (2) makes minor editorial changes.

Date of issuance: July 18, 1995 Effective date: July 18, 1995, to be implemented within 30 days of issuance

Amendment Nos.: Unit 2 -Amendment No. 122; Unit 3 -Amendment No. 111

Facility Operating License Nos. NPF-10 and NPF-15: The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: Unit 2 - July 7, 1993 (58 FR 36445); Unit 3 - June 23, 1993 (58 FR 34094). The two supplemental letters dated July 6, 1994, and the January 27, 1995, supplemental letter provided clarifying information and did not change the initial no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 18, 1995. No significant hazards consideration comments received: No

Local Public Document Room location: Main Library, University of California, P. O. Box 19557, Irvine, California 92713.

Tennessee Valley Authority, Docket Nos. 50-259, 50-260, and 50-296, Browns Ferry Nuclear Plant, Units 1, 2, and 3, Limestone County, Alabama

Date of application for amendments: March 30, 1994

Brief description of amendment: The amendments implement an analog transmitter/trip system on BFN Unit 3, revise the reactor vessel water level safety limit and limiting safety system setting for BFN Units 1 and 3, add

instrument identifiers and revise calibration frequencies and functional test requirements for BFN Unit 2, revise the calibration frequency for instrumentation actuating the suppression chamber-reactor building vacuum breakers, and provide editorial changes.

Date of issuance: July 17, 1995
Effective date: July 17, 1995
Amendment Nos.: 222, 237, 196
Facility Operating License Nos. DPR-33, DPR-52 and DPR-68: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: September 28, 1994(59 FR 49435) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 17, 1995.No significant hazards consideration comments received: None

Local Public Document Room location: Athens Public library, South Street, Athens, Alabama 356114.

Toledo Edison Company, Centerior Service Company, and The Cleveland Electric Illuminating Company, Docket No. 50-346, Davis-Besse Nuclear Power Station, Unit No. 1, Ottawa County, Ohio

Date of application for amendment: January 30, 1995

Brief description of amendment: The proposed amendment revises reactor coolant system pressure-temperature curves, changes bases for Technical Specification 3/4.4.9, Pressure Temperature Limits, and revises License Condition 2.C(3)(d) to reflect a change from 10 effective full power years (EFPY) to 21 EFPY.

Date of issuance: July 20, 1995
Effective date: July 20, 1995
Amendment No.: 199
Facility Operating License No. NPF-3.
Amendment revised the Technical
Specifications.

Date of initial notice in Federal Register: March 15, 1995 (60 FR 14029)The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 20, 1995.No significant hazards consideration comments received: No

Local Public Document Room location: University of Toledo Library, Documents Department, 2801 Bancroft Avenue, Toledo, Ohio 43606.

Union Electric Company, Docket No. 50-483, Callaway Plant, Unit 1, Callaway County, Missouri

Date of application for amendment: September 8, 1994

Brief description of amendment: The amendment revises Technical Specifications (TS) 4.2.2.2, 4.2.2.4, and 6.9.19. The changes address