

The letters of May 20, 1994, and March 8, 1995, provided clarifying information that did not change the initial proposed no significant hazards consideration determination. The Commission's related evaluation of this amendment is contained in a Safety Evaluation dated August 7, 1995. No significant hazards consideration comments received: No.

Local Public Document Room location: Ocean County Library, Reference Department, 101 Washington Street, Toms River, NJ 08753

GPU Nuclear Corporation, et al., Docket No. 50-289, Three Mile Island Nuclear Station, Unit No. 1, Dauphin County, Pennsylvania

Date of application for amendment: April 19, 1994, supplemented March 8, 1995

Brief description of amendment: The amendment revises the TMI-1 Technical Specification (TS) Section 6.5.3 to remove the specified frequency of various licensee-conducted audits, including those related to quality assurance, fire protection, security, emergency preparedness, and offsite dose calculations. The frequencies for conduct of these audits will now be specified in the licensee's Operational Quality Assurance Plan, which requires NRC approval for significant changes. The Commission has determined that these audit frequencies need not be in the TS to assure public health and safety.

Date of issuance: August 14, 1995

Effectove date: August 14, 1995

Amendment No.: 195

Facility Operating License No. DPR-50. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: June 8, 1994 (59 FR 29627) The March 8, 1995, submittal provided clarifying information that did not change the initial proposed no significant hazards consideration determination. The Commission's related evaluation of this amendment is contained in a Safety Evaluation dated August 14, 1995. No significant hazards consideration comments received: No.

Local Public Document Room location: Law/Government Publications Section, State Library of Pennsylvania, (REGIONAL DEPOSITORY) Walnut Street and Commonwealth Avenue, Box 1601, Harrisburg, PA 17105

Niagara Mohawk Power Corporation, Docket No. 50-410, Nine Mile Point Nuclear Station, Unit 2, Oswego County, New York

Date of application for amendment: December 13, 1994, as supplemented April 3, 1995

Brief description of amendment: The amendment revises Table 3.6.1.2-1 to allow a maximum leakage of 24.0 scfh for each of the 8 main steam isolation valves instead of the current 6.0 scfh.

Date of issuance: August 10, 1995

Effectove date: As of the date of issuance to be implemented within 60 days

Amendment No.: 67

Facility Operating License No. NPF-69: Amendment revises the Technical Specifications.

Date of initial notice in Federal Register: January 18, 1995 (60 FR 3675)

The April 3, 1995, letter provided clarifying information that did not change the initial no proposed significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated August 10, 1995. No significant hazards consideration comments received: No

Local Public Document Room location: Reference and Documents Department, Penfield Library, State University of New York, Oswego, New York 13126

Pennsylvania Power and Light Company, Docket Nos. 50-387 and 50-388 Susquehanna Steam Electric Station, Units 1 and 2, Luzerne County, Pennsylvania

Date of application for amendments: March 15, 1995 (published in Federal Register as March 15, 1994) as supplemented by letter dated August 5, 1995

Brief description of amendments: These amendments modify the Susquehanna Steam Electric Station Technical Specification Table 3.6.3-1, Primary Containment Isolation Valves, concerning the scope of Type C testing on specified emergency core cooling system and reactor core isolation cooling containment isolation valves. Specifically, the subject valves on systems which terminate below the minimum water level of the suppression pool will no longer require Type C testing but will instead be tested using requirements of the American Society of Mechanical Engineers' Section XI Code.

Date of issuance: August 15, 1995

Effectove date: August 15, 1995

Amendment Nos.: 149 and 119

Facility Operating License Nos. NPF-14 and NPF-22. The amendments revised the Technical Specifications. The supplemental letter did not change the proposed no significant hazards consideration determination nor the Federal Register notice.

Date of initial notice in Federal Register: April 26, 1995 (60 FR 20521)

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated August 15, 1995. No significant hazards consideration comments received: No

Local Public Document Room location: Osterhout Free Library, Reference Department, 71 South Franklin Street, Wilkes-Barre, Pennsylvania 18701

Pennsylvania Power and Light Company, Docket Nos. 50-387 and 50-388 Susquehanna Steam Electric Station, Units 1 and 2, Luzerne County, Pennsylvania

Date of application for amendments: March 31, 1995, as supplemented by letter dated June 22, 1995

Brief description of amendments: These amendments delete from the Technical Specifications of each unit, the operational condition restriction in Surveillance Requirement 4.8.1.1.2.d.7, which requires that 24-hour emergency diesel generator testing be performed with at least one unit in operational condition 4 or 5 (cold shutdown or refueling).

Date of issuance: August 15, 1995

Effectove date: Units 1 and 2, effective as of the date of issuance and shall be implemented within 60 days

Amendment Nos.: 150 and 120

Facility Operating License Nos. NPF-14 and NPF-22. The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: April 26, 1995 (60 FR 20523) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated August 15, 1995. No significant hazards consideration comments received: No

Local Public Document Room location: Osterhout Free Library, Reference Department, 71 South Franklin Street, Wilkes-Barre, Pennsylvania 18701

Pennsylvania Power and Light Company, Docket Nos. 50-387 and 50-388 Susquehanna Steam Electric Station, Units 1 and 2, Luzerne County, Pennsylvania

Date of application for amendments: November 21, 1994, as supplemented by letters dated February 21, 1995, March 28, 1995, April 10, 1995, May 24, 1995, and June 23, 1995

Brief description of amendments: These amendments change the Technical Specifications for the two units by deleting reference to the main steamline isolation valve (MSIV) leakage control system and its associated primary containment isolation valves, and increase the allowable leakage rate for any MSIV and the total maximum