

North Atlantic Energy Service Corporation, Docket No. 50-443, Seabrook Station, Unit No. 1, Rockingham County, New Hampshire

Date of amendment request: May 30, 1995.

Description of amendment request: The amendment revises the Appendix A Technical Specifications (TS) relating to Moderator Temperature Coefficient. The amendment changes the upper limit for the moderator temperature coefficient (MTC) for certain operating conditions. Additionally, a reference for the analytical method used to determine the cycle-specific MTC upper limit is added to TS 6.8.1.6.b.

Date of issuance: September 14, 1995
Effective date: As of the date of issuance to be implemented within 60 days.

Amendment No.: 41
Facility Operating License No. NPF-86. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: July 5, 1995 (60 FR 35082). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 14, 1995. No significant hazards consideration comments received: No

Local Public Document Room location: Exeter Public Library, Founders Park, Exeter, NH 03833

North Atlantic Energy Service Corporation, Docket No. 50-443, Seabrook Station, Unit No. 1, Rockingham County, New Hampshire

Date of amendment request: June 16, 1995

Description of amendment request: The amendment revises the Appendix A Technical Specifications (TS) relating to core reactivity control available from boroated water sources. The amendment changes the minimum boron concentration specified for the refueling water storage tank (RWST) in Limiting Condition for Operation (LCO) in TS 3.1.2.5 and replaces the minimum specified concentration for boron with an acceptable range of boron concentration for the RWST and the accumulators in the LCOs for TS 3.1.2.6, 3.5.1.1, and 3.5.4.

Date of issuance: September 14, 1995
Effective date: As of the date of issuance, to be implemented prior to entering MODE 4 following the fourth refueling outage.

Amendment No.: 42
Facility Operating License No. NPF-86. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: August 2, 1995 (60 FR 39442).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 14, 1995. No significant hazards consideration comments received: No

Local Public Document Room location: Exeter Public Library, Founders Park, Exeter, NH 03833

Northeast Nuclear Energy Company, Docket No. 50-245, Millstone Nuclear Power Station, Unit 1, New London County, Connecticut

Date of application for amendment: July 11, 1995

Brief description of amendment: The amendment modifies Technical Specification 3.5.F.7 to also allow the use of pull-to-lock switches to defeat the automatic initiation of the emergency core cooling system while in the refuel condition. The amendment also makes editorial corrections and makes changes to the associated Bases section.

Date of issuance: September 13, 1995
Effective date: As of the date of issuance to be implemented within 30 days.

Amendment No.: 88
Facility Operating License No. DPR-21. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: August 2, 1995 (60 FR 39442). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 13, 1995. No significant hazards consideration comments received: No
Local Public Document Room location: Learning Resources Center, Three Rivers Community-Technical College, 574 New London Turnpike, Norwich, CT 06360

Northeast Nuclear Energy Company, Docket No. 50-245, Millstone Nuclear Power Station, Unit 1, New London County, Connecticut

Date of application for amendment: July 18, 1995

Brief description of amendment: The amendment adds operability and surveillance requirements for reactor pressure vessel overfill protection instrumentation. The amendment also adds the associated Bases.

Date of issuance: September 13, 1995
Effective date: As of the date of issuance to be implemented within 60 days.

Amendment No.: 87
Facility Operating License No. DPR-21. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: August 2, 1995 (60 FR 39443). The Commission's related evaluation of the amendment is contained in a Safety

Evaluation dated September 13, 1995. No significant hazards consideration comments received: No
Local Public Document Room location: Learning Resources Center, Three Rivers Community-Technical College, 574 New London Turnpike, Norwich, CT 06360

Omaha Public Power District, Docket No. 50-285, Fort Calhoun Station, Unit No. 1, Washington County, Nebraska
Date of amendment request: April 7, 1995

Brief description of amendment: The amendment revises the technical specifications (TS) to relocate the axial power distribution limits to the Core Operating Limits Report (COLR).

Date of issuance: September 1, 1995
Effective date: September 1, 1995
Amendment No.: 170

Facility Operating License No. DPR-40. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: May 23, 1995 (60 FR 27339). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 1, 1995. No significant hazards consideration comments received: No

Local Public Document Room location: W. Dale Clark Library, 215 South 15th Street, Omaha, Nebraska 68102

Omaha Public Power District, Docket No. 50-285, Fort Calhoun Station, Unit No. 1, Washington County, Nebraska

Date of amendment request: May 8, 1995, as supplemented by letter dated July 11, 1995.

Brief description of amendment: The amendment changes Sections 2.3, 3.1, 3.2, 3.3, and 3.6 of the Technical Specifications in accordance with the guidance of Generic Letter (GL) 93-05, "Line Item Technical Specifications Improvements to Reduce Surveillance Requirements for Testing During Power Operation," dated September 27, 1993. The changes are consistent with Station operating experience and NUREG-1366, "Improvements to Technical Specifications Surveillance Requirements," dated December 1992. In addition, a change was made to TS Section 3.1 in accordance with the Commission's Final Policy Statement on Technical Specifications Improvements for Nuclear Power Reactors. Also, changes were made to the TS sections identified above for clarity and to correct administrative errors.

Date of issuance: September 7, 1995
Effective date: September 7, 1995
Amendment No.: 171