

application and did not change the staff's initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated September 28, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room location:* Maud Preston Palenske Memorial Library, 500 Market Street, St. Joseph, Michigan 49085.

Indiana Michigan Power Company, Docket Nos. 50-315 and 50-316, Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2, Berrien County, Michigan

*Date of application for amendments:* May 26, 1995.

*Brief description of amendments:* The amendments modify Technical Specification Sections 3/4.3.1 and 3/4.3.2 and their accompanying Bases, to relocate the tables of response time limits for the reactor trip system and engineered safety feature acutation system instrumentation to the Updated Final Safety Analysis Report.

*Date of issuance:* October 10, 1995.

*Effective date:* October 10, 1995.

*Amendment Nos.:* 202 and 187.

*Facility Operating License Nos. DPR-58 and DPR-74.* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* July 5, 1995 (60 FR 35082) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated October 10, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room location:* Maud Preston Palenske Memorial Library, 500 Market Street, St. Joseph, Michigan 49085.

Maine Yankee Atomic Power Company, Docket No. 50-309, Maine Yankee Atomic Power Station, Lincoln County, Maine

*Date of application for amendment:* May 5, 1995.

*Brief description of amendment:* The amendment revises the surveillance frequency of radiation area, and effluent and process monitors from monthly to quarterly; and the required frequency for minimum exercise of control element assemblies also from monthly to quarterly.

*Date of issuance:* October 2, 1995.

*Effective date:* As of the date of issuance, to be implemented within 30 days.

*Amendment No.:* 153.

*Facility Operating License No. DPR-36:* Amendment revised the Technical Specifications and/or License.

*Date of initial notice in Federal Register:* August 30, 1995 (60 FR

45179). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 2, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room location:* Wiscasset Public Library, High Street, P.O. Box 367, Wiscasset, ME 04578.

Northern States Power Company, Docket No. 50-263, Monticello Nuclear Generating Plant, Wright County, Minnesota

*Date of application for amendment:* June 8, 1994, as superseded by letter dated April 20, 1995, and supplemented by letter dated August 18, 1995.

*Brief description of amendment:* The amendment revises Sections 3.7/4.7, which pertain to the standby gas treatment system (SGTS) and secondary containment. The amendment revises the surveillance requirements for both SGTS and the secondary containment and revises the performance requirements for the SGTS filters and process stream electric heaters.

*Date of issuance:* October 2, 1995.

*Effective date:* October 2, 1995.

*Amendment No.:* 94.

*Facility Operating License No. DPR-22.* Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* July 20, 1994 (59 FR 37075). The April 20 and August 18, 1995, submittals provided clarifying information within the scope of the original submittal and did not change the staff's initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 2, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room location:* Minneapolis Public Library, Technology and Science Department, 300 Nicollet Mall, Minneapolis, Minnesota 55401

Northern States Power Company, Docket Nos. 50-282 and 50-306, Prairie Island Nuclear Generating Plant, Unit Nos. 1 and 2, Goodhue County, Minnesota.

*Date of application for amendments:* July 11, 1994, as supplemented April 18, 1995 (supersedes the February 10, 1993, application).

*Brief description of amendments:* The amendments change license condition 2.C.(4) of each license to conform to the standard fire protection license condition as stated in Generic Letter 86-10. In addition, the amendments delete

fire protection program elements from the Technical Specifications and incorporate, by reference, the NRC-approved Fire Protection Program and major commitments, including the fire hazards analysis, into the Updated Safety Analysis Report.

*Date of issuance:* October 6, 1995.

*Effective date:* October 6, 1995, with full implementation within 30 days.

*Amendment Nos.:* 120 and 113.

*Facility Operating License Nos. DPR-42 and DPR-60.* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* December 21, 1994 (59 FR 65818). The April 18, 1995, letter provided clarifying information within the scope of the original submittal and did not change the staff's initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated October 6, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room location:* Minneapolis Public Library, Technology and Science Department, 300 Nicollet Mall, Minneapolis, Minnesota 55401.

Sacramento Municipal Utility District, Docket No. 50-312, Rancho Seco Nuclear Generating Station, Sacramento County, California

*Date of application for amendment:* June 20, 1995.

*Brief description of amendment:* This amendment modifies the technical specifications on spent fuel storage building load handling limits to allow the placement of the top shield plug on a dry shielded canister containing spent fuel which is being prepared for transfer to the Rancho Seco Independent Spent Fuel Storage Installation.

*Date of issuance:* October 5, 1995.

*Effective date:* October 5, 1995.

*Amendment No.:* 123.

*Facility Operating License No. NPF-1:* The amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* August 30, 1995 (60 FR 45184). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 5, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room location:* Central Library, Government Documents, 828 I Street, Sacramento, California 95814.