

Brief description of amendments: The amendments revise Technical Specification Surveillance Requirement 4.6.1.2 to add the provision that 10 CFR Part 50, Appendix J, applies, except as modified by NRC-approved exemptions.

Date of issuance: November 17, 1995

Effective date: As of the date of issuance to be implemented within 30 days

Amendment Nos.: 91 and 69

Facility Operating License Nos. NPF-68 and NPF-81: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: July 5, 1995 (60 FR 35078) The July 6 and October 2, 1995, letters provided clarifying information that did not change the scope of the May 12, 1995, application and initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated November 17, 1995.

No significant hazards consideration comments received: No

Local Public Document Room

location: Burke County Library, 412 Fourth Street, Waynesboro, Georgia 30830

Northeast Nuclear Energy Company, Docket No. 50-245, Millstone Nuclear Power Station, Unit 1, New London County, Connecticut

Date of application for amendment: July 28, 1995, as supplemented September 12, October 18, and October 31, 1995.

Brief description of amendment: In order to support a full-core offload as a normal end-of-cycle event, the amendment adds License Condition 2.C(6) and will require that: (1) the reactor be subcritical for at least 100 hours prior to the start of reactor refueling operations, (2) the spent fuel pool bulk temperature be maintained less than or equal to 140°F, and (3) two trains of shutdown cooling be operable during reactor refueling operations.

Date of issuance: November 9, 1995

Effective date: As of the date of issuance.

Amendment No.: 89

Facility Operating License No. DPR-21. Amendment revised the license.

Date of initial notice in Federal Register: August 30, 1995 (60 FR 45180) The September 12, October 18, and October 31, 1995, submittals provided additional information that did not change the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment and Final No Significant Hazards Consideration Determination are

contained in a Safety Evaluation dated November 9, 1995.

No significant hazards consideration comments received: No public comments received. A request for a hearing was received from We the People, the Seacoast Anti-Pollution League, the New England Coalition on Nuclear Pollution, and Donald Del Core of Uncasville, Connecticut.

Local Public Document Room

location: Learning Resources Center, Three Rivers Community-Technical College, 574 New London Turnpike, Norwich, CT 06360

Northeast Nuclear Energy Company, et al., Docket No. 50-336, Millstone Nuclear Power Station, Unit No. 2, New London County, Connecticut

Date of application for amendment: October 6, 1995, supplemented October 23, November 2, and November 15, 1995.

Brief description of amendment: The amendment adds footnotes to Action Statement (AS) 3.8.1.1.a of the Technical Specification (TS) and its bases to allow a one-time extension of the allowed outage time (AOT) for an inoperable offsite power source from the current 72 hours to 7 days.

Date of issuance: November 22, 1995

Effective date: As of the date of issuance, to be implemented within 30 days.

Amendment No.: 192

Facility Operating License No. DPR-65. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: October 17, 1995 (60 FR 53812). The October 23, November 2, and November 15, 1995, letters provided clarifying information and slight modifications to the original request that were not outside the scope of the original notice and did not change the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 22, 1995.

No significant hazards consideration comments received: No

Local Public Document Room

location: Learning Resources Center, Three Rivers Community-Technical College, 574 New London Turnpike, Norwich, CT 06360

Northern States Power Company, Docket No. 50-282, Prairie Island Nuclear Generating Plant, Unit No. 1, Goodhue County, Minnesota

Date of application for amendment: January 10, 1995, as supplemented August 9 and September 20, 1995.

Brief description of amendment: The amendments revise the Prairie Island

event monitoring instrumentation Technical Specifications and associated Bases to conform to Standard Technical Specifications for post-accident monitoring.

Date of issuance: November 9, 1995

Effective date: November 9, 1995, with full implementation within 30 days.

Amendment Nos.: 121/114

Facility Operating License No. DPR-42 and DPR-60. Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: February 15, 1995 (60 FR 8753) The August 9 and September 20, 1995, letters provided updated Technical Specification pages and clarifying information in response to discussions with the staff during various teleconferences conducted during the review process. This information was within the scope of the original application and did not change the staff's initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 9, 1995.

No Significant hazards consideration comments received: No

Local Public Document Room

location: Minneapolis Public Library, Technology and Science Department, 300 Nicollet Mall, Minneapolis, Minnesota 55401

Philadelphia Electric Company, Docket Nos. 50-352 and 50-353, Limerick Generating Station, Units 1 and 2, Montgomery County, Pennsylvania

Date of application for amendments: December 2, 1994, as supplemented May 12, 1995.

Brief description of amendments: These amendments relocate the fire protection requirements from the Technical Specifications to the Updated Final Safety Analysis Report in accordance with the guidance in Generic Letter (GL) 86-10, "Implementation of Fire Protection Requirements," and GL 88-12, "Removal of Fire Protection Requirements from Technical Specifications."

Date of issuance: November 20, 1995
Effective date: As of date of issuance, both units, to be implemented within 30 days.

Amendment Nos.: 104 and 68

Facility Operating License Nos. NPF-39 and NPF-85. The amendments revised the Technical Specifications and the License.

Date of initial notice in Federal Register: April 26, 1995 (60 FR 20524) The supplemental letter provided clarifying information and did not