

change the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated November 20, 1995.

No significant hazards consideration comments received: No

Local Public Document Room location: Pottstown Public Library, 500 High Street, Pottstown, Pennsylvania 19464

Philadelphia Electric Company, Docket Nos. 50-352 and 50-353, Limerick Generating Station, Units 1 and 2, Montgomery County, Pennsylvania

Date of application for amendments: September 14, 1995 and supplemented by letter dated October 27, 1995

Brief description of amendments: These amendments revise the technical specifications by deleting Reactor Enclosure and Refueling Area Secondary Containment Isolation Valve Tables 3.6.5.2.1-1 and 3.6.5.2.2-1, and references to them, in accordance with Generic Letter 91-08, "Removal of Component lists from Technical Specifications." The TS have been modified to state requirements in general terms that include the components listed in the tables removed from the TS.

Date of issuance: November 20, 1995
Effective date: As of date of issuance, to be implemented within 30 days.

Amendment Nos.: November 20, 1995
Facility Operating License Nos.: NPF-39 and NPF-85. The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: October 11, 1995 (60 FR 52934) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated November 20, 1995.

No significant hazards consideration comments received: No

Local Public Document Room location: Pottstown Public Library, 500 High Street, Pottstown, Pennsylvania 19464

Tennessee Valley Authority, Docket No. 50-296, Browns Ferry Nuclear Plant, Unit 3, Limestone County, Alabama

Date of application for amendments: October 4, 1995 (TS 368)

Brief description of amendment: The amendment delete requirements for daily checks for certain instruments that do not have indications, and provides editorial changes.

Date of issuance: November 13, 1995
Effective Date: November 13, 1995
Amendment No.: 202

Facility Operating License No.: DPR-68: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: October 11, 1995 (60 FR 52935) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 13, 1995.

No significant hazards consideration comments received: None

Local Public Document Room location: Athens Public library, South Street, Athens, Alabama 35611

Tennessee Valley Authority, Docket Nos. 50-327 and 50-328, Sequoyah Nuclear Plant, Units 1 and 2, Hamilton County, Tennessee

Date of application for amendments: August 7, 1995 (TS 95-03)

Brief description of amendments: The amendments address operation with a rod urgent failure condition, including limited operation with one control or shutdown bank inserted up to 18 steps below its insertion point. In addition, the surveillance interval for rod movement verifications has been increased from 31 to 92 days.

Date of issuance: November 21, 1995

Effective date: November 21, 1995

Amendment Nos.: 215 and 205

Facility Operating License Nos.: DPR-77 and DPR-79: Amendments revise the technical specifications.

Date of initial notice in Federal Register: August 30, 1995 (60 FR 45186) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 21, 1995.

No significant hazards consideration comments received: None

Local Public Document Room location: Chattanooga-Hamilton County Library, 1101 Broad Street, Chattanooga, Tennessee 37402

The Cleveland Electric Illuminating Company, Centerior Service Company, Duquesne Light Company, Ohio Edison Company, Pennsylvania Power Company, Toledo Edison Company, Docket No. 50-440, Perry Nuclear Power Plant, Unit No. 1, Lake County, Ohio

Date of application for amendment: April 28, 1995

Brief description of amendment: The amendment removes the license conditions for the Transamerica Delaval, Inc. emergency diesel generators specified by paragraph 2.C.(9) and defined in Attachment 2 to the Operating License.

Date of issuance: November 16, 1995

Effective date: November 16, 1995

Amendment No.: 74

Facility Operating License No.: NPF-58: This amendment revises the license.

Date of initial notice in Federal Register: June 6, 1995 (60 FR 29889)

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 16, 1995.

No significant hazards consideration comments received: No

Local Public Document Room location: Perry Public Library, 3753 Main Street, Perry, Ohio 44081

Toledo Edison Company, Centerior Service Company, and The Cleveland Electric Illuminating Company, Docket No. 50-346, Davis-Besse Nuclear Power Station, Unit No. 1, Ottawa County, Ohio

Date of application for amendment: June 23, 1995, and facsimile transmission dated October 31, 1995

Brief description of amendment: This amendment relocates TS 3/4.3.3.3, "Seismic Instrumentation;" TS 3/4.3.3.4, "Meteorological Instrumentation;" and TS 3/4.4.11, "Reactor Coolant System Vents;" and the Bases for each of the three sections from the TS to the Updated Safety Analysis Report, and eliminates the special reporting requirements for inoperable seismic and meteorological monitoring instrumentation from TS 6.9.2.

Date of issuance: November 14, 1995
Effective date: November 14, 1995, and shall be implemented not later than 90 days after issuance.

Amendment No.: 201

Facility Operating License No.: NPF-3: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: August 2, 1995 (60 FR 39455) The October 31, 1995, facsimile transmission was clarifying in nature and did not affect the initial no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 14, 1995.

No significant hazards consideration comments received: No

Local Public Document Room location: University of Toledo, William Carlson Library, Government Documents Collection, 2801 West Bancroft Avenue, Toledo, Ohio 43606

Toledo Edison Company, Centerior Service Company, and The Cleveland Electric Illuminating Company, Docket No. 50-346, Davis-Besse Nuclear Power Station, Unit No. 1, Ottawa County, Ohio

Date of application for amendment: June 7, 1995

Brief description of amendment: This amendment revises Technical Specification 3/4.9.4, Refueling Operations - Containment Penetrations;