

Bases 3/4.9.4, Containment Penetrations; and Limiting Condition for Operation (LCO) 3.9.4.b to allow both doors of the containment personnel airlock to be open during core alterations or movement of irradiated fuel within the containment, provided that certain specified conditions are met. Additional changes revise or clarify TS LCO 3.9.4.c, TS Action 3.9.4.a, and TS Surveillance Requirement 4.9.4, and modify the associated Bases.

*Date of issuance:* November 17, 1995

*Effective date:* November 17, 1995

*Amendment No.:* 202

*Facility Operating License No.* NPF-3. Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* August 2, 1995 (60 FR 39454) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 17, 1995.

*No significant hazards consideration comments received:* No

*Local Public Document Room location:* University of Toledo, William Carlson Library, Government Documents Collection, 2801 West Bancroft Avenue, Toledo, Ohio 43606

TU Electric Company, Docket Nos. 50-445 and 50-446, Comanche Peak Steam Electric Station, Unit Nos. 1 and 2, Somervell County, Texas

*Date of amendment request:* December 6, 1994

*Brief description of amendments:* These changes revise Technical Specifications to allow appropriate remedial action for high particulate levels in the diesel generator fuel oil inventory and other out-of-limit properties in new diesel generator fuel oil that has been added to the existing diesel generator fuel oil storage inventory.

*Date of issuance:* November 17, 1995

*Effective date:* November 17, 1995

*Amendment Nos.:* Unit 1 - Amendment No. 43; Unit 2 - Amendment No. 29

*Facility Operating License Nos.* NPF-87 and NPF-89. The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* February 1, 1995 (60 FR 6311) The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated November 17, 1995.

*No significant hazards consideration comments received:* No

*Local Public Document Room location:* University of Texas at Arlington Library, Government Publications/Maps, 702 College, P.O. Box 19497, Arlington, Texas 76019.

Union Electric Company, Docket No. 50-483, Callaway Plant, Callaway County, Missouri

*Date of amendment request:* January 13, 1995

*Brief description of amendment:* The amendment revises Technical Specifications (TS) 3.3.1 and 3.3.2 to relocate Tables 3.3-2 and 3.3-5, which provide the response time limits for the reactor trip system and the engineered safety features actuation system instruments, from the TS to the updated Final Safety Analysis Report (FSAR). The amendment also relocates the Bases discussion for TS 3.3.1 and TS 3.3.2 to Section 16.3 of the updated FSAR.

*Date of issuance:* November 22, 1995

*Effective date:* November 22, 1995, to be implemented within 30 days of issuance.

*Amendment No.:* 104

*Facility Operating License No.* NPF-30. The amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* February 15, 1995 (60 FR 8741) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 22, 1995.

*No significant hazards consideration comments received:* No

*Local Public Document Room locations:* Callaway County Public Library, 710 Court Street, Fulton, Missouri 65251

Washington Public Power Supply System, Docket No. 50-397, Nuclear Project No. 2, Benton County, Washington

*Date of application for amendment:* June 6, 1995

*Brief description of amendment:* The amendment modifies the Index of the WNP-2 Technical Specifications by deleting reference to the Bases pages.

*Date of issuance:* November 24, 1995

*Effective date:* November 24, 1995

*Amendment No.:* 143

*Facility Operating License No.* NPF-21: The amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* July 19, 1995 (60 FR 37102) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 24, 1995.

*No significant hazards consideration comments received:* No

*Local Public Document Room location:* Richland Public Library, 955 Northgate Street, Richland, Washington 99352

Wisconsin Electric Power Company, Docket Nos. 50-266 and 50-301, Point Beach Nuclear Plant, Unit Nos. 1 and 2, Town of Two Creeks, Manitowoc County, Wisconsin

*Date of application for amendments:* September 13, 1995, and October 19, 1995, as supplemented by letter dated October 25, 1995

*Brief description of amendments:* These amendments revise Technical Specification (TS) Section 15.1, "Definitions," TS Section 15.3.1.G, "Operational Limitations" (and basis), and TS Figure 15.2.1-2, "Reactor Core Safety Limits, Point Beach Unit 2." The changes reduce the reactor coolant system raw measured total flow rate limit and reflect new reactor core safety limits for Unit 2.

*Date of issuance:* November 17, 1995

*Effective date:* November 17, 1995

*Amendment Nos.:* 165 and 169

*Facility Operating License Nos.* DPR-24 and DPR-27: Amendments revised the Technical Specifications. Public comments requested as to proposed no significant hazards consideration: Yes (60 FR 54527 dated October 24, 1995). That notice provided an opportunity to submit comments on the Commission's proposed no significant hazards consideration determination. No comments have been received. The notice also provided for an opportunity to request a hearing by November 24, 1995, but indicated that if the Commission makes a final no significant hazards consideration determination any such hearing would take place after issuance of the amendment. The Commission's related evaluation of the amendment, finding of exigent circumstances, and final determination of no significant hazards consideration is contained in a Safety Evaluation dated November 17, 1995.

*No significant hazards consideration comments received:* No

*Local Public Document Room location:* Joseph P. Mann Library, 1516 Sixteenth Street, Two Rivers, Wisconsin 54241

Wolf Creek Nuclear Operating Corporation, Docket No. 50-482, Wolf Creek Generating Station, Coffey County, Kansas

*Date of amendment request:* September 14, 1995

*Brief description of amendment:* The amendment revised Technical Specification 3/4.5.5 to increase the allowed outage time for adjustment of boron concentration for the refueling water storage tank from 1 hour to 8 hours.

*Date of issuance:* November 13, 1995