

Commonwealth Edison Company, Docket Nos. STN 50-454 and STN 50-455, Byron Station, Unit Nos. 1 and 2, Ogle County, Illinois Docket Nos. STN 50-456 and STN 50-457, Braidwood Station, Unit Nos. 1 and 2, Will County, Illinois

Date of application for amendments: November 7, 1994, as supplemented December 16, 1994.

Brief description of amendments: The amendments approve the use and storage of fuel with an enrichment not to exceed a nominal 5.0 weight percent U-235 in the spent fuel racks.

Date of issuance: January 20, 1995.

Effective date: January 20, 1995.

Amendment Nos.: 68, 68, 58, and 58.

Facility Operating License Nos. NPF-37, NPF-66, NPF-72 and NPF-77: The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: December 7, 1994 (59 FR 63115). The December 16, 1994, submittal provided additional clarifying information that did not change the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in an Environmental Assessment dated January 13, 1995, and in a Safety Evaluation dated January 20, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room location: For Byron, the Byron Public Library, 109 N. Franklin, P.O. Box 434, Byron, Illinois 61010; for Braidwood, the Wilmington Township Public Library, 201 S. Kankakee Street, Wilmington, Illinois 60481.

Duke Power Company, Docket Nos. 50-369 and 50-370, McGuire Nuclear Station, Units 1 and 2, Mecklenburg County, North Carolina

Date of application for amendments: January 10, 1994, as supplemented September 15, 1994, January 5 and 10, 1995.

Brief description of amendments: The amendments revise Technical Specification (TS) Table 2.2-1 and TS 4.2.5 to allow a change in the method for measuring reactor coolant system (RCS) flow rate from the calorimetric heat balance method to a method based on a calibration of the RCS cold leg elbow differential pressure taps.

Date of issuance: January 12, 1995.

Effective date: To be implemented within 30 days from the date of issuance.

Amendment Nos.: 153 and 135.

Facility Operating License Nos. NPF-9 and NPF-17: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: February 16, 1994 (59 FR 7688). The September 15, 1994, January 5 and 10, 1995, letters provided clarifying information that did not change the scope of the January 10, 1994, application, the **Federal Register** Notice or the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 12, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room location: Atkins Library, University of North Carolina, Charlotte (UNCC Station), North Carolina 28223

Florida Power and Light Company, et al., Docket Nos. 50-335 and 50-389, St. Lucie Plant, Unit Nos. 1 and 2, St. Lucie County, Florida

Date of application for amendments: November 2, 1994.

Brief description of amendments: These amendments clarify the actions required in the event of inoperable equipment associated with containment depressurization and cooling systems, and provide consistency between Unit 1 and Unit 2 requirements.

Date of Issuance: January 18, 1995.

Effective Date: January 18, 1995.

Amendment Nos.: 131 and 70.

Facility Operating License Nos. DPR-67 and NPF-16: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: December 7, 1994 (59 FR 63122).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 18, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room location: Indian River Junior College Library, 3209 Virginia Avenue, Fort Pierce, Florida 34954-9003.

Florida Power and Light Company, Docket Nos. 50-250 and 50-251, Turkey Point Plant Units 3 and 4, Dade County, Florida

Date of application for amendments: April 19, 1994.

Brief description of amendments: These amendments consist of changes to the Technical Specifications relating to surveillance requirements for inservice inspection and testing programs.

Date of issuance: January 11, 1995.

Effective date: January 11, 1995.

Amendment Nos.: 171 and 165.

Facility Operating Licenses Nos. DPR-31 and DPR-41: Amendments revised the Technical Specifications.

Date of initial notice in Federal

Register: May 25, 1994 (59 FR 27054).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 11, 1995.

No significant hazards consideration comments received: No

Local Public Document Room location: Florida International University, University Park, Miami, Florida 33199.

Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, City of Dalton, Georgia, Docket No. 50-424, Vogtle Electric Generating Plant, Unit 1, Burke County, Georgia

Date of application for amendment: August 16, 1994.

Brief description of amendment: The amendment eliminated License Condition 2.C.(6) and the associated Attachment 1 of the license. License Condition 2.C.(6) referenced Attachment 1 which listed special diesel generator maintenance and surveillance requirements.

Date of issuance: January 20, 1995.

Effective date: To be implemented within 30 days from the date of issuance.

Amendment No.: 81.

Facility Operating License Nos. NPF-68: Amendment revised the Facility Operating License.

Date of initial notice in Federal

Register: September 6, 1994 (59 FR 46071).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 20, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room location: Burke County Library, 412 Fourth Street, Waynesboro, Georgia 30830.

Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, City of Dalton, Georgia, Docket Nos. 50-424 and 50-425, Vogtle Electric Generating Plant, Units 1 and 2, Burke County, Georgia

Date of application for amendments: March 31, 1994.

Brief description of amendments: The changes revised TS Table 3.7-1 by lowering the maximum allowable power range neutron flux high setpoint when one or more main steam safety valves (MSSVs) are inoperable. The changes also revised the Bases for TS 3/4.7.1.1