

Local Public Document Room
location: White Plains Public Library,
100 Martine Avenue, White Plains, New
York 10610.

**Power Authority of The State of New
York, Docket No. 50-286, Indian Point
Nuclear Generating Unit No. 3,
Westchester County, New York**

Date of application for amendment:
December 8, 1994.

Brief description of amendment: The
amendment revises TS section 4.4.E.1 to
allow a one-time extension to the 30-
month interval requirement for leak rate
testing of Residual Heat Removal
containment isolation valves AC-732,
AC-741, AC-MOV-743, AC-MOV-744
and AC-MOV-1870.

Date of issuance: January 13, 1995.

Effective date: As of the date of
issuance to be implemented within 30
days.

Amendment No.: 158.

*Facility Operating License No. DPR-
64:* Amendment revised the Technical
Specifications.

*Date of initial notice in Federal
Register:* December 13, 1994 (59 FR
64223).

The Commission's related evaluation
of the amendment is contained in a
Safety Evaluation dated January 13,
1995.

No significant hazards consideration
comments received: No.

Local Public Document Room
location: White Plains Public Library,
100 Martine Avenue, White Plains, New
York 10610.

**Power Authority of The State of New
York, Docket No. 50-286, Indian Point
Nuclear Generating Unit No. 3,
Westchester County, New York**

Date of application for amendment:
June 29, 1994, as supplemented
December 2, 1994.

Brief description of amendment: The
amendment revised Technical
Specification (TS) Section 6.5, "Review
and Audit," and TS Section 6.8,
"Procedures," to establish a new review
and approval process for nuclear safety-
related procedures and to modify
membership requirements for the Plant
Operating Review Committee. The
amendment also revised TS Section 6.5
to delete review and audit
responsibilities for the Emergency and
Security Plans consistent with Generic
Letter 93-07, "Modification of the
Technical Specification Administrative
Control Requirements for Emergency
and Security Plans."

Date of issuance: January 17, 1995.

Effective date: As of the date of
issuance to be implemented within 90
days.

Amendment No.: 159.

*Facility Operating License No. DPR-
64:* Amendment revised the Technical
Specifications.

*Date of initial notice in Federal
Register:* July 20, 1994 (59 FR 37081).

The Commission's related evaluation
of the amendment is contained in a
Safety Evaluation dated January 17,
1995.

No significant hazards consideration
comments received: No.

Local Public Document Room
location: White Plains Public Library,
100 Martine Avenue, White Plains, New
York 10610.

**Power Authority of the State of New
York, Docket No. 50-333, James A.
FitzPatrick Nuclear Power Plant,
Oswego County, New York**

Date of application for amendment:
June 17, 1994, as supplemented
December 2, 1994.

Brief description of amendment: The
amendment revises Section 6.5,
"Review and Audit," and Section 6.8,
"Procedures," of the Technical
Specifications (TSs) to establish a new
review and approval process for nuclear
safety-related procedures. The
amendment also revises Section 6.5 to
modify membership requirements for
the Plant Operating Review Committee
and to delete review and audit
responsibilities for the Emergency and
Security Plans from the TSs consistent
with Generic Letter 93-07,
"Modification of the Technical
Specification Administrative Control
Requirements for Emergency and
Security Plans."

Date of issuance: January 18, 1995.

Effective date: As of the date of
issuance to be implemented within 90
days.

Amendment No.: 222.

*Facility Operating License No. DPR-
59:* Amendment revised the Technical
Specifications.

*Date of initial notice in Federal
Register:* July 20, 1994 (59 FR 37082).

The Commission's related evaluation
of the amendment is contained in a
Safety Evaluation dated January 18,
1995.

No significant hazards consideration
comments received: No

Local Public Document Room
location: Reference and Documents
Department, Penfield Library, State
University of New York, Oswego, New
York 13126.

**The Cleveland Electric Illuminating
Company, Centerior Service Company,
Duquesne Light Company, Ohio Edison
Company, Pennsylvania Power
Company, Toledo Edison Company,
Docket No. 50-440, Perry Nuclear
Power Plant, Unit No. 1, Lake County,
Ohio**

Date of application for amendment:
September 19, 1994.

Brief description of amendment: The
amendment revised the Technical
Specifications for the snubber visual
inspection schedule.

Date of issuance: January 20, 1995.

Effective date: January 20, 1995 and to
be implemented within 90 days.

Amendment No.: 68.

*Facility Operating License No. NPF-
58:* This amendment revised the
Technical Specifications.

*Date of initial notice in Federal
Register:* October 26, 1994 (59 FR
53843).

The Commission's related evaluation
of the amendment is contained in a
Safety Evaluation dated January 20,
1995.

No significant hazards consideration
comments received: No.

Local Public Document Room
location: Perry Public Library, 3753
Main Street, Perry, Ohio 44081.

**Toledo Edison Company, Centerior
Service Company, and The Cleveland
Electric Illuminating Company, Docket
No. 50-346, Davis-Besse Nuclear Power
Station, Unit No. 1, Ottawa County,
Ohio**

Date of application for amendment:
May 1, 1992 as clarified by facsimile
transmission dated January 10, 1995.

Brief description of amendment: The
amendment revises the LIMITING
CONDITIONS FOR OPERATION and
SURVEILLANCE REQUIREMENTS for
the containment air locks, changes the
exception for containment penetration
status verification to include the
annulus, clarifies containment air lock
testing intervals, and clarifies the
definition and bases for containment
integrity.

Date of issuance: January 17, 1995.

Effective date: Date of issuance and to
be implemented within 90 days.

Amendment No.: 194.

Facility Operating License No. NPF-3.
Amendment revised the Technical
Specifications.

*Date of initial notice in Federal
Register:* September 2, 1992 (57 FR
40221).

The Commission's related evaluation
of the amendment is contained in a
Safety Evaluation dated January 17,
1995.