

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* University of Toledo Library, Documents Department, 2801 Bancroft Avenue, Toledo, Ohio 43606.

**Washington Public Power Supply System, Docket No. 50-397, Nuclear Project No. 2, Benton County, Washington**

*Date of application for amendment:* August 8, 1994.

*Brief description of amendment:* The amendment modifies the Technical Specifications (TS) to delete the requirement to obtain prior written relief from the Commission for inservice inspection (ISI) and inservice testing (IST) of components conducts pursuant to 10 CFR 50.55a. The amendment also adds a definition for the word "biennial."

*Date of issuance:* January 5, 1995.

*Effective date:* January 5, 1995.

*Amendment No.:* 133.

*Facility Operating License No. NPF-21:* The amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 14, 1994 (59 FR 56558).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 5, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Richland Public Library, 955 Northgate Street, Richland, Washington 99352.

**Wisconsin Electric Power Company, Docket Nos. 50-266 and 50-301, Point Beach Nuclear Plant, Unit Nos. 1 and 2, Town of Two Creeks, Manitowoc County, Wisconsin**

*Date of application for amendments:* November 23, 1993, as supplemented January 10, 12, and 13, 1995.

*Brief description of amendments:* These amendments revise the operating conditions and limiting conditions for operation for containment systems, and revise corresponding definitions and tests. In addition, the related bases are updated to ensure consistency and clarity.

*Date of issuance:* January 18, 1995.

*Effective date:* January 18, 1995, to be implemented within 45 days.

*Amendment Nos.:* 160 and 164.

*Facility Operating License Nos. DPR-24 and DPR-27.* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* January 19, 1994 (59 FR 2875).

The Commission's related evaluation of the amendments is contained in a

Safety Evaluation dated January 18, 1995.

The January 10, 12, and 13, 1995 submittals provided supplemental information that did not change the initial proposed no significant hazards consideration determination.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Joseph P. Mann Library, 1516 Sixteenth Street, Two Rivers, Wisconsin 54241.

**Wolf Creek Nuclear Operating Corporation, Docket No. 50-482, Wolf Creek Generating Station, Coffey County, Kansas**

*Date of amendment request:* October 27, 1993.

*Brief description of amendment:* The amendment changes Note 5 of Technical Specification Table 4.3-1 to reflect the use of integral bias curves, rather than detector plateau curves, to calibrate the source range instrumentation.

*Date of issuance:* January 9, 1995.

*Effective date:* January 9, 1995, to be implemented within 30 days.

*Amendment No.:* 83.

*Facility Operating License No. NPF-42.* The amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 24, 1993 (58 FR 62159). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 9, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*locations:* Emporia State University, William Allen White Library, 1200 Commercial Street, Emporia, Kansas 66801 and Washburn University School of Law Library, Topeka, Kansas 66621.

**Wolf Creek Nuclear Operating Corporation, Docket No. 50-482, Wolf Creek Generating Station, Coffey County, Kansas**

*Date of amendment request:* October 21, 1994, as supplemented by letters dated October 27, 1994 and December 2, 1994.

*Brief description of amendment:* This amendment revises Technical Specification (TS) Surveillance Requirements 4.7.1.2.1.c.2, operability testing of the auxiliary feedwater (AFW) pump auto start feature, and 4.3.2.2, engineered safety features (ESF) time response testing of the AFW pumps to exempt the testing of the turbine-driven AFW pump from the provisions of TS 4.0.4 for entry into Mode 3. In addition, TS Surveillance Requirement 4.7.1.2.1.c is revised to delete the requirement that

the 18 month AFW surveillance be performed during shutdown.

*Date of issuance:* January 20, 1995.

*Effective date:* January 20, 1995, to be implemented within 30 days.

*Amendment No.:* 84.

*Facility Operating License No. NPF-42.* The amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 23, 1994 (59 FR 60389) The December 2, 1994, supplemental letter provided clarifying information and did not change the initial no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 20, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*locations:* Emporia State University, William Allen White Library, 1200 Commercial Street, Emporia, Kansas 66801 and Washburn University School of Law Library, Topeka, Kansas 66621.

Dated at Rockville, Maryland, this 25th day of January 1995.

For the Nuclear Regulatory Commission.

**Jack W. Roe,**

*Director, Division of Reactor Projects—III/IV, Office of Nuclear Reactor Regulation.*

[FR Doc. 95-2350 Filed 1-31-95; 8:45 am]

BILLING CODE 7590-01-P

## SECURITIES AND EXCHANGE COMMISSION

[Release No. 34-35278; File No. SR-CBOE-95-02]

### Self-Regulatory Organizations; Notice of Filing of Proposed Rule Change by the Chicago Board Options Exchange, Inc. Relating to the Listing of Long-Term Index Options Series ("LEAPS") With a Duration of Up to Sixty Months Until Expiration

January 25, 1995.

Pursuant to Section 19(b)(1) of the Securities Exchange Act of 1934 ("ACT"),<sup>1</sup> and Rule 19b-4 thereunder,<sup>2</sup> notice is hereby given that on January 19, 1995, the Chicago Board Options Exchange ("CBOE" or "Exchange") filed with the Securities and Exchange Commission ("Commission") the proposed rule change as described in Items I, II, and III below, which Items have been prepared by the CBOE. The Commission is publishing this notice to

<sup>1</sup> 15 U.S.C. § 78s(b)(1) (1988).

<sup>2</sup> 17CFR 240.19b-4 (1991).