

comments relating to the proposed Consent Decree. Comments should be addressed to the Assistant Attorney General for the Environment and Natural Resources Division, Department of Justice, Washington, DC 20530, and should refer to *United States v. General Motors Corporation*, DOJ Ref. #90-5-2-1-2011 and 2011A.

The proposed Consent Decree may be examined at the Office of the United States Attorney, Judiciary Center Bldg., 555 Fourth St. NW., Washington, DC 20001; at the Environmental Protection Agency Library, Reference Desk, Room 2904, 401 M Street SW., Washington, DC 20460; and at the Consent Decree Library, 1120 G Street NW., 4th Floor, Washington, DC 20005, 202-624-0892. A copy of the proposed Consent Decree may be obtained in person or by mail from the Consent Decree Library, 1120 G Street NW., 4th Floor, Washington, DC 20005. In requesting a copy, please refer to the referenced case and enclose a check in the amount of \$18.75 (25 cents per page reproduction costs), payable to the Consent Decree Library.

Joel M. Gross,

Chief, Environmental Enforcement Section.

[FR Doc. 95-30055 Filed 12-8-95; 8:45 am]

BILLING CODE 4410-01-M

OFFICE OF NATIONAL DRUG CONTROL POLICY

National Consultation on Drug Control

AGENCY: Office of National Drug Control Policy.

ACTION: The Office of National Drug Control Policy (ONDCP) is requesting an emergency review under the Paperwork Reduction Act. This is because ONDCP is required by law to deliver the 1996 National Drug Control Strategy and Budget document to the Congress in February, 1996, and the subject consultation is critical to the development of that Strategy.

SUMMARY: The Office of National Drug Control Policy, Executive Office of the President, in carrying out its responsibilities under the Paperwork Reduction Act (44 U.S.C. Chapter 35, 5 CFR 1320 {53 FR 16618, May 10, 1988}), is submitting a request to conduct a National Consultation on Drug Control, entitled "Consult With America." The ONDCP consultation survey instrument will be used to assess public opinion regarding perceptions of the use and impact of illicit drugs; the effectiveness of prevention, intervention and treatment programs; and level of public support for specific drug control actions. A telephone survey of a random

sample of adults 18 years of age and older will be conducted.

DATES: ONDCP has requested an emergency review of this submission under the Paperwork Reduction Act; this Office of Management and Budget (OMB) review has been requested to be completed by December 8, 1995.

FOR FURTHER INFORMATION CONTACT:

Comments and questions regarding the National Survey on Drug Control should be directed to Mr. N. Ross Deck, Senior Policy Analyst, Office of National Drug Control Policy, Executive Office of the President, 750 17th Street NW., Washington, DC 20500, (202) 395-6736. Any member of the public who wants to comment on the information collection request which has been submitted to OMB should advise Mr. Deck of this intent at the earliest possible date.

Average Burden Hours/Minutes per Response: 12 Minutes.

Frequency of Response: One time data collection.

Number of Respondents: 2,000.

Total Annual Burden Hours: 400.

Total Annual Response: 2,000.

Affected Public: Non-institutional adult (18 years of age or older) population residing in the U.S. at the household level.

Respondents Obligation to Replay: The survey is voluntary.

SUPPLEMENTARY INFORMATION: None.

Signed at Washington, DC, this 1st day of December, 1995.

N. Ross Deck,

Senior Policy Analyst.

[FR Doc. 95-30030 Filed 12-8-95; 8:45 am]

BILLING CODE 3180-02-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-440]

Cleveland Electric Illuminating Company, Centerior Service Company, Duquesne Light Company, Ohio Edison Company, Pennsylvania Power Company, Toledo Edison Company (Perry Nuclear Power Plant, Unit 1); Exemption

I

Cleveland Electric Illuminating Company, (the licensee) is the holder of Facility Operating License No. NPF-58, which authorizes operation of the Perry Nuclear Power Plant, Unit 1 (PNPP). The operating license provides, among other things, that the licensee is subject to all rules, regulations, and orders of the Commission now and hereafter in effect.

The facility consists of a single boiling water reactor located at the licensee's site in Lake County, Ohio.

II

Containment leak rate testing is necessary to demonstrate that the measured leak rate is within the acceptance criteria cited in the licensing design basis. Periodic testing of the overall containment structure along with separate leak testing of the penetrations provides assurance that post-accident radiological consequences will be within the limits of 10 CFR Part 100. The Commission's requirements regarding leak rate testing are found in Appendix J to 10 CFR Part 50.

In its letter dated October 21, 1994, the licensee applied for partial exemptions from the Commission's regulations. The subject exemptions, which are from the requirements in Appendix J, Option A, to 10 CFR Part 50, include:

- Section III.A.5(b)(2) states that the measured leakage from the containment integrated leak rate (Type A) test (L_{am}) shall be less than 75% of the maximum allowable leakage rate (0.75 L_a).

- Sections III.B.3 and III.C.3 require that the combined leakage of valves and penetrations subject to Type B and C local leak rate testing be less than 0.6 times the maximum allowable leakage rate (0.6 L_a).

- Section III.A.1(d) requires that all fluid systems that would be open to containment following post-accident conditions, be vented and drained prior to conducting the containment integrated leak rate test.

- Section III.D.1(a) states that the third Type A test of each 10-year interval be conducted when the plant is shut down for the 10-year plant inservice inspection.

- Section III.D.3 states that Type C tests shall be performed during each reactor shutdown for refueling but in no case at intervals greater than 2 years. Type C tests are tests intended to measure containment isolation valve leakage rates.

III

Section III.A.5(b)(2) states that the measured leakage from the containment integrated leak rate (Type A) test (L_{am}) shall be less than 75% of the maximum allowable leakage rate (0.75 L_a). The licensee proposes to exempt main steam line isolation valve leakage from Type A test results and consider leakage from the main steam lines separately. Sections III.B.3 and III.C.3 require that the combined leakage of valves and penetrations subject to Type B and C local leak rate testing be less than 0.6