

College, Oglesby, Illinois; and for Quad Cities Station, Dixon Public Library, 221 Hennepin Avenue, Dixon, Illinois.

Connecticut Yankee Atomic Power Company, Docket No. 50-213, Haddam Neck Plant, Middlesex County, Connecticut

*Date of amendment request:*  
November 14, 1995

*Description of amendment request:*  
The notice relates to your November 14, 1995, application to amend the Technical Specifications to provide a one-time exception to the Technical Specification 3.9.12, "Fuel Building Storage Air Cleanup System," to allow the fuel storage building air cleanup system to be inoperable during intervals in which new fuel rack modules will be moved into and old fuel modules will be moved out of the fuel storage building.

*Date of publication of individual notice in Federal Register:* November 28, 1995 (60 FR 58688)

*Expiration date of individual notice:*  
December 28, 1995

*Local Public Document Room location:* Russell Library, 123 Broad Street, Middletown, CT 06457.

*Attorney for licensee:* Lillian M. Cuoco, Esq., Senior Nuclear Counsel, Northeast Utilities Service Company, P.O. Box 270, Hartford, CT 06141-0270.

*NRC Project Director:* Phillip F. McKee

Duke Power Company, et al., Docket Nos. 50-413 and 50-414, Catawba Nuclear Station, Units 1 and 2, York County, South Carolina

*Date of amendment request:* January 12, 1995, as supplemented by letter dated June 29, 1995

*Description of amendment request:*  
The proposed amendments would modify portions of Technical Specification Section 6.0, "Administrative Controls."

*Date of publication of individual notice in Federal Register:* November 24, 1995, (60 FR 58109)

*Expiration date of individual notice:*  
December 26, 1995

*Local Public Document Room location:* York County Library, 138 East Black Street, Rock Hill, South Carolina 29730

Duke Power Company, et al., Docket Nos. 50-413 and 50-414, Catawba Nuclear Station, Units 1 and 2, York County, South Carolina

*Date of amendment request:*  
September 5, 1995

*Description of amendment request:*  
The proposed amendments would revise the Updated Final Safety Analysis Report.

*Date of publication of individual notice in Federal Register:* November 28, 1995 (60 FR 58690)

*Expiration date of individual notice:*  
December 28, 1995

*Local Public Document Room location:* York County Library, 138 East Black Street, Rock Hill, South Carolina 29730

Niagara Mohawk Power Corporation, Docket Nos. 50-220 and 50-410, Nine Mile Point Nuclear Station, Unit Nos. 1 and 2, Oswego County, New York

*Date of amendments request:* October 25, 1995

*Description of amendments request:*  
The proposed amendments would change position titles and reassign responsibilities at the upper management level to reflect a restructuring of Niagara Mohawk's upper management organization.

*Date of publication of individual notice in Federal Register:* November 16, 1995 (60 FR 57605)

*Expiration date of individual notice:*  
December 18, 1995

*Local Public Document Room location:* Reference and Documents Department, Penfield Library, State University of New York, Oswego, New York 13126.

Northeast Nuclear Energy Company, Docket No. 50-245, Millstone Nuclear Power Station, Unit 1, New London County, Connecticut

*Date of amendment request:* October 3, 1995

*Description of amendment request:*  
The notice relates to your October 3, 1995, application to amend the Technical Specifications to remove the Limiting Condition for Operation (LCO) and Surveillance Requirements for the loss-of-normal power (LNP) trip function from Tables 3.2.2 and 4.2.1 and insert new LCO 3.2.F and Surveillance Requirement 4.2.F. In addition, the proposed amendment will add a new table to specify the required LNP instrumentation for each bus, will update the Table of Contents, will make some editorial changes, and will revise the associated Bases section.

*Date of publication of individual notice in Federal Register:* December 4, 1995 (60 FR 62111).

*Expiration date of individual notice:*  
January 3, 1996

*Local Public Document Room location:* Learning Resources Center, Three Rivers Community-Technical College, 574 New London Turnpike, Norwich, CT 06360.

Notice Of Issuance Of Amendments To Facility Operating Licenses

During the period since publication of the last biweekly notice, the Commission has issued the following amendments. The Commission has determined for each of these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for A Hearing in connection with these actions was published in the Federal Register as indicated.

Unless otherwise indicated, the Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments. If the Commission has prepared an environmental assessment under the special circumstances provision in 10 CFR 51.12(b) and has made a determination based on that assessment, it is so indicated.

For further details with respect to the action see (1) the applications for amendment, (2) the amendment, and (3) the Commission's related letter, Safety Evaluation and/or Environmental Assessment as indicated. All of these items are available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document rooms for the particular facilities involved.

Arizona Public Service Company, et al., Docket Nos. STN 50-528, STN 50-529, and STN 50-530, Palo Verde Nuclear Generating Station, Units 1, 2, and 3, Maricopa County, Arizona

*Date of application for amendments:*  
July 3, 1995

*Brief description of amendments:* The amendment temporarily adds new Action Statements 3.8.1.1.f and 3.8.1.1.g to Technical Specification 3.8.1.1, "A.C. Sources - Operating," to provide a method of responding to sustained degraded voltage. Also, Bases 3/4.8.1, 3/4.8.2, and 3/4.8.3 (≥A.C. Sources," "D.C. Sources," and "Onsite Distribution