

*Date of Issuance:* January 27, 1995.

*Effective Date:* January 27, 1995.

*Amendment No.:* 132.

*Facility Operating License No. DPR-67:* Amendment revised the Technical Specifications.

*Date of initial notice in Federal*

**Register:** August 17, 1994 (59 FR 42341).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 27, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Indian River Junior College Library, 3209 Virginia Avenue, Fort Pierce, Florida 34954-9003.

*Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, City of Dalton, Georgia, Docket Nos. 50-424 and 50-425, Vogtle Electric Generating Plant, Units 1 and 2, Burke County, Georgia*

*Date of application for amendments:* February 3, 1994.

*Brief description of amendments:* The amendments relocate the requirements of Technical Specification 3/4.7.10, Area Temperature Monitoring, to section 16.3 of the VEGP Final Safety Analysis Report (FSAR). With this relocation to the FSAR, GPC plans to clarify the basis for areas to be monitored and modify these surveillance requirements. This change is in accordance with NUREG-1431, "Standard Technical Specifications, Westinghouse Plants."

*Date of issuance:* January 23, 1995.

*Effective date:* To be implemented within 30 days from the date of issuance.

*Amendment Nos.:* 83 and 61.

*Facility Operating License Nos. NPF-68 and NPF-81:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal*

**Register:** September 2, 1994 (59 FR 45735).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 23, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Burke County Library, 412 Fourth Street, Waynesboro, Georgia 30830.

*GPU Nuclear Corporation, et al., Docket No. 50-289, Three Mile Island Nuclear Station, Unit No. 1, Dauphin County, Pennsylvania*

*Date of application for amendment:* May 13, 1992.

*Brief description of amendment:* The amendment changes the allowable primary-to-secondary leakage rate, as specified in License Condition 2.c.(8)2, from 0.1 gallons per minute (gpm) to 0.2 gpm.

*Date of Issuance:* January 31, 1995.

*Effective date:* January 31, 1995.

*Amendment No.:* 193.

*Facility Operating License No. DPR-50.* Amendment revises a License Condition.

*Date of initial notice in Federal*

**Register:** October 14, 1992 (57 FR 47137).

The Commission's related evaluation of this amendment is contained in a Safety Evaluation dated January 31, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Government Publications Section, State Library of Pennsylvania, Walnut Street and Commonwealth Avenue, Box 1601, Harrisburg, Pennsylvania 17105.

*Nebraska Public Power District, Docket No. 50-298, Cooper Nuclear Station, Nemaha County, Nebraska*

*Date of amendment request:*

September 26, 1994.

*Brief description of amendment:* The amendment revised Technical Specification 3.5.C.1 and 3.5.C.4 to increase the minimum pressure at which the high pressure coolant injection system is required to be operable from 113 psig to 150 psig.

*Date of issuance:* January 25, 1995.

*Effective date:* January 25, 1995.

*Amendment No.:* 166.

*Facility Operating License No. DPR-46.* Amendment revised the Technical Specifications.

*Date of initial notice in Federal*

**Register:** October 26, 1994 (59 FR 53841). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 25, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Auburn Public Library, 118 15th Street, Auburn, Nebraska 68305.

*Nebraska Public Power District, Docket No. 50-298, Cooper Nuclear Station, Nemaha County, Nebraska*

*Date of amendment request:*

December 22, 1994.

*Brief description of amendment:* The amendment revised Technical Specification 1.0.J, definition of limiting conditions for operation, consistent with the guidance provided in NRC Generic Letter 87-09, "Sections 3.0 and

4.0 of the Standard Technical Specifications on the Applicability of Limiting Conditions for Operation and Surveillance Requirements."

*Date of issuance:* February 3, 1995.

*Effective date:* February 3, 1995.

*Amendment No.:* 168.

*Facility Operating License No. DPR-46.* Amendment revised the Technical Specifications.

*Date of initial notice in Federal*

**Register:** January 3, 1995 (60 FR 153).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated February 3, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Auburn Public Library, 118 15th Street, Auburn, Nebraska 68305.

*Niagara Mohawk Power Corporation, Docket No. 50-220, Nine Mile Point Nuclear Station Unit No. 1, Oswego County, New York.*

*Date of application for amendment:* July 21, 1994.

*Brief description of amendment:* The amendment revises Technical Specifications 2.2.2, 3.2.8, 4.2.8, and the associated Bases to reduce the number of reactor head safety valves required operable from 16 valves to 9 valves. The setpoints of the valve groups are unchanged by this amendment. The amendment requires testing of the safety valves in accordance with the approved NMP-1 Inservice Test Program.

*Date of issuance:* January 25, 1995.

*Effective date:* As of the date of issuance to be implemented within 30 days.

*Amendment No.:* 152.

*Facility Operating License No. DPR-63:* Amendment revises the Technical Specifications.

*Date of initial notice in Federal*

**Register:** August 31, 1994 (59 FR 45027).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 25, 1995.

No significant hazards consideration comments received: No.

*Local Public Document Room*

*location:* Reference and Documents Department, Penfield Library, State University of New York, Oswego, New York 13126.

*Niagara Mohawk Power Corporation, Docket No. 50-410, Nine Mile Point*

*Nuclear Station, Unit 2, Oswego County, New York.*

*Date of application for amendment:* October 28, 1994.

*Brief description of amendment:* The amendment revises Technical