

wetwell sample lines. This change is based on the licensee's design change for installation of a new CRM and wetwell sample system.

*Date of issuance:* January 31, 1995.

*Effective date:* January 31, 1995.

*Amendment Nos.:* 141 and 111.

*Facility Operating License Nos. NPF-14 and NPF-22.* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* December 7, 1994 (59 FR 63126). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 31, 1995.

*No significant hazards consideration comments received:* No.

*Local Public Document Room location:* Osterhout Free Library, Reference Department, 71 South Franklin Street, Wilkes-Barre, Pennsylvania 18701.

*Philadelphia Electric Company, Docket No. 50-352, Limerick Generating Station, Unit 1, Montgomery County, Pennsylvania.*

*Date of application for amendment:* June 10, 1994, as supplemented by letter dated December 19, 1994.

*Brief description of amendment:* This amendment involves a one-time change affecting the Allowed Outage Time (AOT) for the Emergency Service Water (ESW) system, Residual Heat Removal Service Water (RHRSW) System, the Suppression Pool Cooling, the Suppression Pool Spray, and Low Pressure Coolant Injection modes of the Residual Heat Removal System, and Core Spray System to be extended from 3 and 7 days to 14 days during the Unit 2 refueling outage scheduled to begin in January 1995. This proposed extended AOT allows adequate time to install isolation valves and cross-ties on the ESW and RHRSW Systems to facilitate future inspections or maintenance.

*Date of issuance:* January 27, 1995.

*Effective date:* January 27, 1995.

*Amendment No.:* 86.

*Facility Operating License No. NPF-39.* This amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* July 20, 1994 (59 FR 37077). The December 19, 1994 letter provided clarifying information that did not change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 27, 1995.

*No significant hazards consideration comments received:* No.

*Local Public Document Room location:* Pottstown Public Library, 500

High Street, Pottstown, Pennsylvania 19464.

*Philadelphia Electric Company, Docket No. 50-353, Limerick Generating Station, Unit 2, Montgomery County, Pennsylvania.*

*Date of application for amendment:* June 30, 1994.

*Brief description of amendment:* This amendment removes the controls for a remote shutdown system control valve and the primary containment isolation valves from TS Tables 3.3.7.4-1 and 3.6.3-1 respectively, as a result of eliminating the steam condensing mode of the Residual Heat Removal system.

*Date of issuance:* January 27, 1995.

*Effective date:* January 27, 1995.

*Amendment No.:* 47.

*Facility Operating License No. NPF-85.* This amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* August 17, 1994 (59 FR 42343).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 27, 1995.

*No significant hazards consideration comments received:* No.

*Local Public Document Room location:* Pottstown Public Library, 500 High Street, Pottstown, Pennsylvania 19464.

*Philadelphia Electric Company, Docket No. 50-353, Limerick Generating Station, Unit 2, Montgomery County, Pennsylvania.*

*Date of application for amendment:* August 27, 1993, supplemented by letter dated November 17, 1993.

*Brief description of amendment:* The amendment allows an expanded operating domain for the Limerick Generating Station (LGS), Unit 2, resulting from the implementation of the Average Power Range Monitor—Rod Block Monitor Technical Specifications/Maximum Extended Load Line Limit Analysis. These improvements are a prerequisite for Power Rerate Program implementation at Limerick Generating Station, Unit 2.

*Date of issuance:* January 27, 1995.

*Effective date:* January 27, 1995.

*Amendment No.:* 48.

*Facility Operating License No. NPF-85.* The amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* October 13, 1993 (58 FR 52992).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 27, 1995.

*No significant hazards consideration comments received:* No.

*Local Public Document Room location:* Pottstown Public Library, 500 High Street, Pottstown, Pennsylvania 19464.

*Philadelphia Electric Company, Docket Nos. 50-352 and 50-353, Limerick Generating Station, Units 1 and 2, Montgomery County, Pennsylvania.*

*Date of application for amendments:* August 22, 1994.

*Brief description of amendments:* These amendments revise TS 3.1.5, "Standby Liquid Control System," to remove the requirement for the standby liquid control system to be operable in OPERATIONAL CONDITION 5, Refueling, when any control rod is withdrawn and the TS definition of CORE ALTERATION to exclude control rod movement in a control cell that contains no fuel assemblies.

*Date of issuance:* January 27, 1995.

*Effective date:* January 27, 1995.

*Amendment Nos.:* 87/49.

*Facility Operating License Nos. NPF-39 and NPF-85.* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 9, 1994 (59 FR 55881).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 27, 1995.

*No significant hazards consideration comments received:* No.

*Local Public Document Room location:* Pottstown Public Library, 500 High Street, Pottstown, Pennsylvania 19464.

*Power Authority of the State of New York, Docket No. 50-333, James A. FitzPatrick Nuclear Power Plant, Oswego County, New York.*

*Date of application for amendment:* September 28, 1993.

*Brief description of amendment:* The amendment revised Technical Specification (TS) Section 4.11.D to change the surveillance requirements for the Emergency Service Water System pumps. The change added pump flow rate requirements and tests the pumps in accordance with the licensee's Inservice Testing Program. The respective TS Bases were also revised.

*Date of issuance:* January 30, 1995.

*Effective date:* As of the date of issuance to be implemented within 30 days.

*Amendment No.:* 223.

*Facility Operating License No. DPR-59:* Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 24, 1993 (58 FR 62156).