



Utilizar sibologia
Norma EDC
DNI - ND-E-B-01-95

Indicar datos de las
unidades a instalar
en Picture

La Rotación de fases
(T1-T3-T2)
corresponde a las
unidades a instalar ?

APLICAN LOS MISMOS COMENTARIOS DEL PLANO
0906 - 60-001-2I- Rev B

INCLUIR CAJETIN
DE LA EDC

LEGEND:

- AVR-AUTO VOLTAGE REGULATOR
- BFX-TRANSUDCER, BUS FREQUENCY (RUNNING)
- BVX-TRANSUDCER, BUS VOLTAGE (1=INCOMING) (2=RUNNING)
- CBCT1-SWITCH, CIRCUIT BREAKER CONTROL "52G"
- CCCT1-TRANSFORMER, CROSS CURRENT COMPENSATION
- CT1-TRANSFORMER, CURRENT
- DCS-DISTRIBUTED CONTROL SYSTEM
- DGP-DIGITAL GENERATOR PROTECTION SYSTEM
- DMMF-METER, DIGITAL MULTI-FUNCTION
- DSM(15/25)-SYNCHRONIZER, AUTO SPEED-VOLTAGE MATCHING
- EAX-TRANSUDCER, EXCITER FIELD CURRENT
- EAX-TRANSUDCER, EXCITER FIELD VOLTAGE
- EXC-EXCITER
- FPP-PANEL, FIRE PROTECTION
- FUEL-CONTROL, FUEL
- GTG-GAS TURBINE GENERATOR
- GVX-TRANSUDCER GENERATOR VOLTAGE
- K75-RELAY, GTG BUS SYNCHRONIZER ENABLE (52-1)
- K84-RELAY, CIRCUIT BREAKER CLOSE (52G)
- K85-RELAY, CIRCUIT BREAKER TRIP (52G)
- K95/96-RELAY, DEAD BUS (SWITCHGEAR BUS A)
- K114-RELAY, DSM GEN SENSE ENABLE
- LA-ARRESTOR, LIGHTNING
- PMG-PERMANENT MAGNET GENERATOR
- R-RESISTOR
- RG-RESISTOR, GROUNDING
- RTD-DETECTOR, RESISTANCE TEMPERATURE
- SC-CAPACITOR, SURGE
- SL#-LAMPS, SYNCHRONIZING
- SRP-SENSOR, REAL POWER
- SY-METER, SYNCHROSCOPE
- TG-TRANSFORMER, GROUNDING
- VIB-MONITOR, VIBRATION
- VT-TRANSFORMER, VOLTAGE
- WX-TRANSUDCER, WAIT
- 5BF-BREAKER FAIL RELAY
- 24INV-VOLT/Hz INVERSE TIME RELAY
- 24T-RELAY, OVER EXCITATION, GENERATOR VOLTS/HERTZ
- 25AB-RELAY, SYNC-CHECK
- 27-RELAY, UNDERVOLTAGE
- 32-RELAY, DIRECTIONAL POWER (ANTI-MOTERING)
- 40-RELAY, FIELD (EXCITATION LOSS)
- 41-FIELD BREAKER/SUPPRESSOR
- 46-RELAY, CURRENT UNBALANCE
- 50/27-OVERCURRENT UNDER VOLTAGE
- 51V-RELAY, TIME OVERCURRENT, VOLTAGE RESTRAINED
- 52G-AC CIRCUIT BREAKER, GENERATOR
- 59-RELAY, OVERVOLTAGE
- 59N-NEUTRAL OVERVOLTAGE RELAY
- 64(RG)-RELAY, GROUND FAULT
- 64G-RELAY, STATOR GROUNDING
- 74-RELAY ALARM
- 810/U-RELAY, OVER/UNDER FREQUENCY
- 86G-RELAY, LOCKOUT (SHOWN RESET), GENERATOR
- 871-DIFFERENTIAL PROTECTION RELAY
- 94-RELAY, TRIP

REFERENCE DRAWING:

60-001 SH 6 ONE LINE DIAGRAM

NOTES:

1. DMMF INCLUDES THE FOLLOWING: VOLTS, AMPS, POWER FACTOR, KW, KVA, KVAR, FREQUENCY, KVAH, AND KWH.

REVISED

CUSTOMER INFORMATION

© COPYRIGHT 2008 ProEnergy SERVICES. ALL RIGHTS RESERVED.
THIS DRAWING IS THE PROPERTY AND/OR CONFIDENTIAL
PROPERTY OF ProEnergy SERVICES AND IS LOANED IN
STRICT CONFIDENCE WITH THE UNDERSTANDING THAT IT WILL
NOT BE REPRODUCED NOR USED FOR ANY PURPOSE EXCEPT
THAT FOR WHICH IT IS LOANED. IT SHALL BE IMMEDIATELY
RETURNED ON DEMAND, AND IS SUBJECT TO ALL OTHER TERMS
AND CONDITIONS OF ANY WRITTEN AGREEMENT OR PURCHASE
ORDER WHICH INCORPORATES OR RELATES TO THIS DRAWING.

NO.	DATE	BY	APP'D	DESCRIPTION	REVISIONS
B	8/09/09	SEP		ADDED CT'S, REVISED TO TAG #	

CHECK	REB	7/1/09
DESIGN	RS	7/1/09
PROJ ENGR		
QA MGR		

807 & DETROIT
SUITE 140
TULSA, OKLAHOMA 74120
OFFICE 906-829-5100
FAX 918-270-2839
www.proenergyservices.com

ProEnergy EPC Services, LLC
ONE LINE DIAGRAM
GTG 400, LM-2500 PROTECTION
TACOA POWER PLANT
CHARGE JOB NO. 0906
DWG NO. 60-001
SH NO. 9
REV B