




NOTE: "A"
GTG-100 IS A PC DESIGN UNIT AND HAS
"NOX WATER INJECTION"
GTG-200 IS A PD DESIGN AND DOES NOT
HAVE "NOX WATER INJECTION".



asincro c.d.
Ingeniería Integral de Proyectos

REVISADO

VER COMENTARIOS

EDG International

REVISIONS

NO.	DATE	BY	APP'D	DESCRIPTION	REVISIONS
E	10/04/09	S.P.		REMOVED TR-C & CHANGED PANEL TO 480 3/P	
D	8/17/09	EB		REMOVED STARTER SIZE. INSERTED TR-C	
C	8/09/09	BA		REPLACED OCS WITH TSH & ADDED BARK RATING	
B	7/29/09	BA		REVISE TP	

DESIGN: BJA, 07/15/09
CHECK: NS, 7/1/09
PROJ ENGR: PROJ ENGR
PROJ MGR: QA MGR

ProEnergy EPC Services, LLC
ONE LINE DIAGRAM
GTG MCC-100
TACOA POWER PLANT

807 S DETROIT
SUITE 1400
TULSA, OKLAHOMA 74120
OFFICE: 918-270-6100
FAX: 918-270-2839
WWW.PROENERGYSPCSERVICES.COM

0906 60-002 1 E